

Plan Review Resubmittal

Plan Check #: _____ Date: _____

Job Address: _____ Project Name: _____

Project Contact: _____ Phone #: _____

E-mail: _____ Fax#: _____

Resubmittal for Cycle 2 Cycle 3 Cycle 4* Cycle 5* Beyond* __ # of plans submitted _____ EPC

DISCIPLINE	CHECK EACH DISCIPLINE BEING REROUTED	ANY CHANGES TO PREVIOUSLY APPROVED PLANS?*		ANY CHANGES TO THE ORIGINALLY PROPOSED SCOPE OF WORK?*	
		Yes	No	Yes	No
BUILDING (STRUCTURAL):					
LIFE-SAFETY:					
PLUMBING:					
MECHANICAL:					
ELECTRICAL:					
FIRE:					
PLANNING:					
DEVELOPMENT ENGINEERING:					
UTILITIES:					
LANDSCAPE ARCHITECT:					
AIR QUALITY:					
CONSTRUCTION DEBRIS:					
ALL DISCIPLINES UPDATE HOURS IN COMPUTER		COUNTER TECHNICIAN:			

Description of any changes to previously approved plans*: _____

Description of any changes/revisions to the originally proposed scope of work and associated additional valuation*: _____

*Permit applications requiring more than three (3) cycles of plan review or having been redesigned after the original submittal may incur additional hourly plan review fees. I understand that I am responsible for all plan check fees that I incur during the course of this additional plan check and that any approval plans not claimed and paid for within 3 months of notification will be disposed of and an invoice procedure for the amount due will be initiated. I further understand that an unclaimed deferral may result in delay of final approval for the subject project.

Project Contact Signature:  Date: _____

Please note that once this document is submitted to the City of Sacramento, your information may be subject to the Public Records Request Act. However, the City will not sell your data or information for any purpose.



City of Sacramento
Community Department
300 Richards Blvd, 3rd Floor
Sacramento, CA 92811
(916)264-5011

Attention: Jason Queener

May 23, 2023

Re: 905 North Avenue
Building Permit #: COM-2307306
Address: 905 North Avenue

All changes are clouded with revision #1 for clarity.

Electrical Comments

1. Provide a SMUD Commitment Letter.

Please see attached SMUD Substructure Plan. Because this is considered a residential project by SMUD, this is what they have issued in lieu of commitment letter and sketch.

2. All conductors shall be metered as this is private property.

Meter shown on single line.

3. Show service conductors on the single line.

Single line has been revised to note service conductors.

4. Add a note to the plans that the lights mounted on the buildings will be under separate permits and are shown for photometric purposes only.

Note added to plans.

Sincerely
Alex Batista, PE

• HVAC Design
• Plumbing Design
• Electrical Design
• Title 24 Calculations
& Reports
• Energy Management
& Expense Reduction



City of Sacramento
Community Department
300 Richards Blvd, 3rd Floor
Sacramento, CA 92811
(916)264-5011

Attention: Vincent Wang

May 17, 2023

Re: 905 North Avenue
Building Permit #: COM-2307306
Address: 905 North Avenue

All changes are clouded with revision #1 for clarity.

Electrical Comments

1. Detail 1: Detail references structural for light pole anchorage and footing specifications, which were not found. Please provide specifications with supporting structural calculations. Additionally, provide light pole specifications specific to the project on plan (e.g., light fixture weight, light pole height/size, etc.)

Fixture weight added to schedule. Attached are fixture, pole, and structural detail.

Sincerely
Alex Batista, PE

- HVAC Design
- Plumbing Design
- Electrical Design
- Title 24 Calculations
& Reports
- Energy Management
& Expense Reduction

CWE responses in blue



PAGE	SHEET	NAME
1	C1	TITLE SHEET
2	C2.1	GENERAL NOTES 1
3	C2.2	GENERAL NOTES 2
4	C3	EXISTING CONDITIONS
5	C4	OFF-SITE DEMOLITION PLAN
6	C5	NORTH AVENUE PLAN AND PROFILE
7	C6	OFF-SITE UTILITY PLAN
8	C7	OFF-SITE GRADING, EROSION & SEDIMENT CONTROL PLAN
9	C8	OFF-SITE EROSION & SEDIMENT CONTROL NOTES & DETAILS
10	C9	CONSTRUCTION DETAILS
11	C10	SIGNING AND STRIPING PLAN
12	CE0	ELECTRICAL POWER OFF-SITE PLAN (BY OPTIMIZED)
13	L1	LANDSCAPE NOTES AND DETAILS (BY MSLA)
14	L2	PLANTING & IRRIGATION PLAN (BY MSLA)

BENCHMARK 278-A2C
A HILTI NAIL IN LIGHT BASE OF SE CORNER OF DRY CREEK ROAD AND NORTH AVENUE.
ELEV: 40.402' (NAVD88)

SUBJECT PROPERTY IS LOCATED WITHIN ZONE "X", WITH A REDUCED RISK OF FLOODING DUE TO LEVEE. AS DETERMINED BY THE NATIONAL FLOOD INSURANCE PROGRAM, FLOOD INSURANCE RATE MAP COMMUNITY PANEL NO.: 06067C0064 DATED: 06/16/2015

THE EXISTING CURB, GUTTER AND SIDEWALK ALONG THE FRONTAGE OF 905 NORTH AVENUE WILL BE WIDENED 5.5' WITH NEW ROLLED CURB AND GUTTER WITH A DETACHED PUBLIC SIDEWALK. TWO UTILITY POLES WILL BE REQUIRED TO BE RELOCATED AS A RESULT OF THE WIDENING.

NERRADSCALI CORPORATION
3960 KINGSBARN DRIVE
ROSEVILLE, CA 95747

CONTACT: DARREN BROWN
PH: (916) 300-7962
EMAIL: DARRENBROWN@COMCAST.NET

R-2A MULTI-DWELLING UNIT ZONING

APN: 237-0200-092

EXISTING PARCEL 1 = 0.207 ACRES
EXISTING PARCEL 2 = 1.129 ACRES
EXISTING PARCEL 3 = 0.074 ACRES



Call before you

Call before you dig.
or (800) 227-2600

MICHAEL DEQUINE AND ASSOCIATES, INC.
1431 NORTH MARKET BOULEVARD, SUITE 7
SACRAMENTO, CA 95834

CONTACT: MICHAEL DEQUINE, L.S.
PH: (916) 285-0519
EMAIL MDEQUINE@MDEQUINE.COM
LICENSE NUMBER: LS 5614

CITY OF SACRAMENTO

EXISTING: RESIDENTIAL AND VACANT LAND
PROPOSED: MULTI-FAMILY DWELLING

UTILITY REPRESENTATIVES			
UTILITY	COMPANY	CONTACT	PHONE
GAS	PG&E	DONNY KENNEDY	530-889-5089
ELECTRIC	S.M.U.D.	BLANDON GRANGER	916-732-5016
TELEPHONE	AT&T	ASTRID WILLARD	916-453-6136
DRAINAGE, WATER, SEWER	CITY OF SACRAMENTO	JESUS REYES	916-808-1721
U.S.A.	UNDERGROUND SERVICE ALERT		800-227-2600
FIRE	CITY OF SACRAMENTO	KING TUNSON	916-808-1358

SUBMITTED BY: _____ DATE _____

ROBERT F. EYNCK, PE C040666

ACCEPTED BY: _____ DATE _____

CHAD COPEMAN, PE C76393

SENIOR ENGINEER, DEVELOPMENT ENGINEERING

UTILITIES DEPARTMENT DATE _____

ABBREVIATIONS:

AB	AGGREGATE BASE	INV	INVERT
AC	ASPHALT CONCRETE	LT	LEFT TURN
ARV	AIR RELEASE VALVE	LGTR	LIP OF GUTTER
BC	BEGIN CURVE	OMP	OPEN METAL PIPE
BCR	BEGIN CURB RETURN	(P)	PROPOSED
BOP	BOTTOM OF PIPE	PCC	PORTLAND CEMENT CONCRETE
BOW	BACK-OF-WALK	PG	PROFILE GRADE
BR	BOTTOM OF RAMP	PV	POST INDICATOR VALVE
BSE	BUILDING SETBACK EASEMENT	POC	POINT OF CONNECTION
C	CENTERLINE	PL	PROPERTY LINE
CMP	CORRUGATED METAL PIPE	PUE	PUBLIC UTILITY EASEMENT
COTG	CLEAN-OUT TO GRADE	RCP	REINFORCED CONCRETE PIPE
DI	DROP INLET	ROW	RIGHT-OF-WAY
DIP	DUCTILE IRON PIPE	RT	RIGHT TURN
DS	DOWN SPOUT	RPPA	REDUCED PRINCIPAL PRESSURE ASSEMBLY
(E)	EXISTING	SDMH	STORM DRAIN MANHOLE
EC	END CURVE	STORM	STORM DRAIN
ECR	END CURB RETURN	SS	SANITARY SEWER
EP	EDGE OF PAVEMENT	SSCO	SANITARY SEWER CLEAN OUT
FES	FLARED END SECTION	SSMH	SANITARY SEWER MANHOLE
FDC	FIRE DEPARTMENT CONNECTION	SWCT	SAWCUT
FF	FINISH FLOOR	SW	SIDEWALK
FG	FINISHED GROUND	STA	STATION
FH	FIRE HYDRANT	TBC	TOP OF BACK OF CURB
FL	FLOW LINE	TBW	TOP OF BACK OF SIDEWALK
FG	FINISH GRADE	TC	TOP OF CURB
F.O.C.	FACE OF CURB	TCF	TOP OF FACE OF CURB
FS	FIRE SPRINKLER	TOP	TOP OF PIPE
GB	GRADE BREAK	TP	TOP OF PAVEMENT
GR	GRATE	TR	TOP OF RAMP
GV	GATE VALVE	TS	TOP OF SIDEWALK
GWV	GROSS VEHICLE WEIGHT	TG	TOP OF GRATE
HC	HANDICAP	W	WATER
HP	HIGH POINT	WV	WATER VALVE
IRR	IRRIGATION	WM	WATER METER

CUT: 125 CY
FILL: 0 CY
NET: 125 CY EXPORT

NOTE:
EARTHWORK QUANTITIES ARE ESTIMATED TO SUBGRADE AND DO NOT TAKE INTO ACCOUNT SHRINKAGE, EXCESS MATERIALS FROM TRENCHING AND MISC. UNKNOWN STRUCTURAL SECTIONS. CONTRACTOR SHOULD VERIFY EARTHWORK QUANTITIES.

PRIOR TO THE START OF ANY CIVIL WORK, IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY THE HORIZONTAL AND VERTICAL LOCATIONS OF ALL EXISTING UTILITIES BY POTHOLING AT ALL POINTS OF POTENTIAL CONFLICT WITH PROPOSED UTILITIES OR PROPOSED POINTS OF CONNECTION WITH EXISTING UTILITIES. IF THE ACTUAL LOCATIONS OF THE EXISTING UTILITIES FOUND IN THE FIELD ARE DIFFERENT FROM WHAT IS SHOWN ON THESE PLANS, THE CONTRACTOR SHALL CONTACT RFE ENGINEERING IMMEDIATELY AND PROVIDE THE ACTUAL LOCATION INFORMATION. RFE ENGINEERING WILL VERIFY IF THERE ARE ANY CONFLICTS WITH THE IMPROVEMENTS AND WILL PROVIDE MODIFICATIONS TO THE DESIGN TO MITIGATE THE CONFLICTS IF ANY CONFLICTS EXIST.

THIS PROJECT HAS AN APPROVED STATE GENERAL CONSTRUCTION PERMIT AND
STORMWATER POLLUTION PREVENTION PLAN (SWPPP). WDID # 5S34C400468

CONTRACTOR IS RESPONSIBLE TO HIRE A STATE CERTIFIED QSP (QUALIFIED SWPPP PRACTITIONER) TO OVERSEE IMPLEMENTATION OF THE SWPPP PRIOR TO START OF CONSTRUCTION. ALL REQUIRED INSPECTIONS, TRAINING AND REQUIRED TESTING AND REPORTING SHALL BE OVERSEEN BY THE QSP.

THE FINAL APPROVED SWPPP SHALL BE KEPT ON THE CONSTRUCTION SITE DURING CONSTRUCTION AND MAINTAINED BY THE QSP.

CONTRACTOR SHALL SEND THE FINAL SWPPP WITH ALL INSPECTION, TESTING, AMENDMENTS, REPORTS AND OTHER DOCUMENTATION TO THE OWNER ONCE CONSTRUCTION HAS BEEN COMPLETED AND THE NOTICE OF TERMINATION SUBMITTED.

CONTRACTOR SHALL HAVE A PRECONSTRUCTION MEETING AND INCLUDE THE QSP AND CIVIL ENGINEER IN THE MEETING, EITHER ON-SITE OR VIA TELEPHONE CONFERENCE.

OFF-SITE DISTURBED AREA: 0.103 ACRES (OFF-SITE)
ON-SITE DISTURBED AREA: 1.291 ACRES (ON-SITE)
TOTAL DISTURBED AREA: 1.394 ACRES (ON AND OFF-SITE)

REVISIONS			
NO.	DESCRIPTION	DATE	BY

BENCH MARK	ELEV. 40.402'
DESCRIPTION	(NAVD88)
278-A2C	
A HILT NAIL IN LIGHT BASE OF SE	
CORNER OF DRY CREEK ROAD AND	
NORTH AVENUE.	


FIELD BOOK
SCALE HORIZ. 1"=30 VERT. _____

CITY OF SACRAMENTO
DEPARTMENT OF PUBLIC WORKS

DRAWN BY: <u>DCJ</u> DATE <u>03/31/2023</u>	DESIGNED BY: <u>M. WILSON</u> R.C.E. <u>C 92447</u>	CHECKED BY: <u>R. EYNCK</u> R.C.E. <u>C040666</u> DATE <u>6/12/23</u>
--	--	--



2260 Douglas Blvd, Suite 160, Roseville, CA 9566
Ph: 916-772-7800 | www.cwecorp.com



OFF-SITE IMPROVEMENT PLANS FOR
NERRADSCALI SUBDIVISION
SACRAMENTO, CA 95838
APN: 237-0200-092

TITLE SHEET

SHEET
C1
— OF —
14


FOR REFERENCE ONLY

W:\2021 Projects\21-188 905 North Ave Sac\Working CAD\C1 OFFSITE TITLE.dwg Jun 12, 2023-10:22 am

REF PROJECT NO 21-188 - 905 NORTH AVENUE SACRAMENTO CA 95838

W:\2021 Projects\21-188 905 North Ave Sac\Working CAD\ONSITE C1 TITLE.dwg Jun 14 2023-03:11 pm

1 of 14
6/12/2023




1. THE UNDERGROUND UTILITIES SHOWN HAVE BEEN LOCATED FROM FIELD SURVEY INFORMATION AND EXISTING DRAWINGS. THE SURVEYOR MAKES NO GUARANTEE THAT THE UNDERGROUND UTILITIES SHOWN COMPRISE ALL SUCH UTILITIES IN THE AREA, EITHER IN SERVICE OR ABANDONED. THE SURVEYOR FURTHER DOES NOT GUARANTEE THAT THE UNDERGROUND UTILITIES SHOWN ARE IN THE EXACT LOCATION INDICATED ALTHOUGH HE DOES CERTIFY THAT THEY ARE LOCATED AS ACCURATELY AS POSSIBLE FROM INFORMATION AVAILABLE. THE SURVEYOR HAS NOT PHYSICALLY LOCATED THE UNDERGROUND UTILITIES.
2. SEE SHEET C1 FOR BENCHMARK, BASIN OF BEARINGS, AND FLOODPLAIN DESIGNATION.
3. EXISTING CONDITIONS ARE BASED ON A FIELD SURVEY AS REFERENCED ON SHEET C1.
4. PRIOR TO THE START OF ANY CIVIL WORK, IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY THE HORIZONTAL AND VERTICAL LOCATIONS OF ALL EXISTING UTILITIES BY POT-HOLING AT ALL POINTS OF POTENTIAL CONFLICT WITH PROPOSED UTILITIES OR PROPOSED POINTS OF CONNECTION WITH EXISTING UTILITIES. IF THE ACTUAL LOCATIONS OF THE EXISTING UTILITIES FOUND IN THE FIELD ARE DIFFERENT FROM WHAT IS SHOWN ON THESE PLANS, THE CONTRACTOR SHALL CONTACT RFE ENGINEERING IMMEDIATELY AND PROVIDE THE ACTUAL LOCATION INFORMATION. RFE ENGINEERING WILL VERIFY IF THERE ARE ANY CONFLICTS WITH THE IMPROVEMENTS AND WILL PROVIDE MODIFICATIONS TO THE DESIGN TO MITIGATE THE CONFLICTS IF ANY CONFLICTS EXIST.

THE UNDERGROUND UTILITIES SHOWN HAVE BEEN LOCATED FROM FIELD SURVEY INFORMATION AND EXISTING DRAWINGS. THE SURVEYOR MAKES NO GUARANTEE THAT THE UNDERGROUND UTILITIES SHOWN COMPRISE ALL SUCH UTILITIES IN THE AREA, EITHER IN SERVICE OR ABANDONED. THE SURVEYOR FURTHER DOES NOT GUARANTEE THAT THE UNDERGROUND UTILITIES SHOWN ARE IN THE EXACT LOCATION INDICATED ALTHOUGH HE DOES CERTIFY THAT THEY ARE LOCATED AS ACCURATELY AS POSSIBLE FROM INFORMATION AVAILABLE. THE SURVEYOR HAS NOT PHYSICALLY LOCATED THE UNDERGROUND UTILITIES.

[illegible]


Sheet

6/12/2023



DEMOLITION LEGEND:

DEMOLISH AND REMOVE




TREE TO BE REMOVED



DEMOLITION PLAN NOTES:

- SAWCUT AND REMOVE EXISTING ASPHALT PAVEMENT AND PORTLAND CEMENT CONCRETE SIDEWALKS AND CURB AND GUTTERS WITHIN THE LIMITS OF DEMOLITION. ENGINEER SHALL VERIFY LIMITS OF DEMOLITION. PROTECT EXISTING PAVEMENTS AND IMPROVEMENTS TO REMAIN.
2. THE DISPOSAL OF ALL DEBRIS IS THE RESPONSIBILITY OF THE CONTRACTOR AND IT SHALL BE DISPOSED OF OFF-SITE IN ACCORDANCE WITH ALL APPLICABLE CITY, COUNTY, STATE AND FEDERAL REGULATIONS. ANY PERMITS REQUIRED FOR SUCH DISPOSAL ARE THE RESPONSIBILITY OF THE CONTRACTOR.
3. SAWCUT ASPHALT 2' MIN FROM (E) CURB, (P) CURB OR AS OTHERWISE SHOWN ON PLANS.
4. REMOVE EXISTING VEGETATION, MULCH, IRRIGATION, AND OTHER AS REQUIRED IN AREA OF PROJECT IMPROVEMENTS. CAP AND RELOCATE IRRIGATION AS NEEDED. SEE LANDSCAPE PLANS.
5. EXISTING FACILITIES (e.g. IRRIGATION, ELECTRICAL) TO REMAIN SHALL BE PROTECTED DURING CONSTRUCTION. SEE APPLICABLE LANDSCAPE, ELECTRICAL AND ARCHITECTURAL PLANS.
6. REMOVE EXISTING PCC TO LIMITS SHOWN. SAWCUT AT EXISTING SCORE AND/OR EXPANSION JOINTS WHEN POSSIBLE.
7. ANY WORK IN THE CITY ROW SHALL REQUIRE A TRAFFIC CONTROL PLAN PRIOR TO THE ISSUANCE OF ANY PERMIT.
8. ANY PAVEMENT CUT AND REPAIR WITHIN THE CITY ROW SHALL BE REPAIRED PER CITY OF SACRAMENTO STANDARDS.
9. THE CONTRACTOR SHALL COMPLY WITH PROVISIONS OF THE SAFETY AND HEALTH REGULATION FOR CONSTRUCTION PROMULGATED BY THE SECRETARY OF LABOR UNDER SECTION 107 OF THE CONTRACT WORK HOURS AND SAFETY STANDARDS ACT (40 USC 327 ET SEQ.) AS SET FORTH IN TITLE 29, C.F.R., CALOSHIA, AND THE REGULATIONS ISSUED THEREUNDER. COMPLIANCE SHALL BE THE CONTRACTOR'S SOLE RESPONSIBILITY.
10. THE CONTRACTOR SHALL COMPLY WITH CURRENT CALIFORNIA FIRE CODE (FCF), CALIFORNIA CODE OF REGULATIONS, (CCR) TITLE 24, PART 9, ARTICLE 87 - FIRE SAFETY DURING CONSTRUCTION ALTERATION OR DEMOLITION OF A BUILDING, SECTION 8706 - FIRE SAFETY DURING DEMOLITION.
11. THE CONTRACTOR SHALL PROVIDE 72 HOUR NOTICE TO THE OWNER AND ANY AFFECTED UTILITY COMPANIES PRIOR TO COMMENCEMENT OF ANY DEMOLITION ACTIVITIES.
12. EXISTING UTILITIES: LOCATE, IDENTIFY, DISCONNECT AND SEAL OR CAP OFF INDICATED UTILITIES TO BE DEMOLISHED. EXISTING UNUSED SERVICES SHALL BE ABANDONED.
13. PROTECT EXISTING LANDSCAPING MATERIALS, APPURTENANCES, AND STRUCTURES WHICH ARE NOT TO BE DEMOLISHED. PROVIDE TEMPORARY IRRIGATION WHEN IRRIGATION SUPPLY TO BE DISRUPTED.
14. CONTRACTOR SHALL BE RESPONSIBLE FOR PREVENTING MOVEMENT OR SETTLEMENT OF ADJACENT STRUCTURES, AND PROTECTION OF ADJACENT UNDERGROUND UTILITIES. CONTRACTOR SHALL PROVIDE BRACING AND SHORING WHEN REQUIRED.
15. EXISTING UTILITIES TO BE REMOVED: DEMOLISH AND REMOVE EXISTING BELOW GRADE UTILITIES UNLESS OTHERWISE NOTED.
16. REMOVE MATERIALS TO BE RE-INSTALLED OR RETAINED IN MANNER TO PREVENT DAMAGE. STORE AND PROTECT.
17. BACKFILL OPEN PITS AND HOLES CAUSED AS A RESULT OF DEMOLITION WITH EXCESS SOIL ON SITE PER RECOMMENDATIONS CONTAINED IN THE SOILS REPORT FOR BACKFILL MATERIAL.
18. UNIFORMLY ROUGH GRADE AND COMPACT AREAS AFFECTED BY DEMOLITION TO MAINTAIN SITE GRADES AND CONTOURS.
19. CONTRACTOR SHALL BE RESPONSIBLE FOR SECURITY OF CONSTRUCTION AREA AND PROTECTION OF PUBLIC SAFETY DURING ALL TIMES DURING DEMOLITION WORK.
20. **HAZARDOUS MATERIALS:**
 - A. THE CONTRACTOR SHALL COMPLY WITH ALL REQUIREMENTS, PROCEDURES, AND ABATEMENT SPECIFICATIONS FOR THE SAFE REMOVAL OF HAZARDOUS WASTE MATERIALS.
 - B. IF MATERIALS SUSPECTED OF CONTAINING HAZARDOUS MATERIALS ARE ENCOUNTERED, DO NOT DISTURB. NOTIFY ENGINEER & ARCHITECT.
 - C. CONFORM TO APPLICABLE REGULATORY PROCEDURES WHEN DISCOVERING HAZARDOUS OR CONTAMINATED MATERIALS.
21. PROTECT (E) IRRIGATION AND MAINTAIN TO ALL LANDSCAPE AREAS NOT DISTURBED BY THE PROJECT DURING CONSTRUCTION.
22. CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING WITH APPLICABLE DRY UTILITY AGENCIES FOR ABANDONMENT OR REMOVAL OF EXISTING SERVICES PRIOR TO COMMENCEMENT OF SITE DEMOLITION. THE OWNER AND ENGINEER WILL NOT BE HELD RESPONSIBLE FOR ANY DAMAGES OR CLAIMS RESULTING FROM FAILURE TO PROPERLY COORDINATE WITH DRY UTILITY AGENCIES.
23. CONTRACTOR SHALL IMPLEMENT CITY OF SACRAMENTO TREE PRESERVATION REQUIREMENTS, SEE NOTES ON SHEET C2.2.
24. INSTALL 20X10" CHAIN LINK FENCING AROUND EXISTING TREES TO REMAIN PRIOR TO DEMOLITION. COMPLY WITH TREE PROTECTION MEASURES IN GENERAL NOTES. SEE SHEET C2.2.
25. EXISTING IMPROVEMENTS THAT ARE DETERMINED DETERIORATED BY THE PUBLIC WORKS INSPECTOR DURING CONSTRUCTION OR AT FINAL WALK THRU INSPECTION SHALL BE RECONSTRUCTED TO THE SATISFACTION OF PUBLIC WORKS. CONSTRUCTION SHALL BE COMPLETED PRIOR TO THE ISSUANCE OF NOTICE OF COMPLETION (NOC). ALL COSTS ASSOCIATED WITH THIS RECONSTRUCTION SHALL BE THE RESPONSIBILITY OF THE PROPERTY OWNER AND/OR CONTRACTOR.



2260 Douglas Blvd, Suite 160, Roseville, CA 95661
Ph: 916-772-7800 | www.cwacorn.com

PROPERTY OWNER / DEVELOPER
NERRASCALI CORPORATION
3960 KINGSBARN DRIVE
ROSEVILLE, CA 95747

CONTACT: DARREN BROWN
PH: (916) 300-7962
EMAIL: DARRENBROWN@COMCAST.NET

ON-SITE IMPROVEMENT PLANS FOR
NERRADSCALI SUBDIVISION
SACRAMENTO, CA 95838
APN: 237-0200-092

DEMOLITION PLAN

Sheet


C4

5 of 14


6/12/2023



Know what's **below**.
Call before you dig
 or (800) 227-2600



N:\2021 Projects\21-188 905 North Ave Sac\Working CAD\ONSITE C5 HORIZONTAL CNTL.dwg Jun 14, 2023-03:11 pm



NOTES:

DIMENSIONS ARE TO BOTTOM FACE OF CURB UNLESS SPECIFIED OTHERWISE. BUILDING OUTLINE REPRESENT THE OUTER-MOST ELEMENT OF BUILDINGS. CONTRACTOR SHALL REFER TO FOUNDATION PLANS FOR CONSTRUCTION OF FOUNDATION AND BUILDING SLAB.

UNDERGROUND UTILITY NOTE:

THE UNDERGROUND UTILITIES SHOWN HAVE BEEN LOCATED FROM FIELD SURVEY INFORMATION AND EXISTING DRAWINGS. THE SURVEYOR MAKES NO GUARANTEE THAT THE UNDERGROUND UTILITIES SHOWN COMPRISE ALL SUCH UTILITIES IN THE AREA, EITHER IN SERVICE OR ABANDONED. THE SURVEYOR FURTHER DOES NOT GUARANTEE THAT THE UNDERGROUND UTILITIES SHOWN ARE IN THE EXACT LOCATION INDICATED ALTHOUGH HE DOES CERTIFY THAT THEY ARE LOCATED AS ACCURATELY AS POSSIBLE FROM INFORMATION AVAILABLE. THE SURVEYOR HAS NOT PHYSICALLY LOCATED THE UNDERGROUND UTILITIES.

NOTICE TO CONTRACTOR - ORDER OF WORK:

PRIOR TO THE START OF ANY CIVIL WORK, IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY THE HORIZONTAL AND VERTICAL LOCATIONS OF ALL EXISTING UTILITIES BY POT-HOLING AT ALL POINTS OF POTENTIAL CONFLICT WITH PROPOSED EXISTING OR PROPOSED JOINTS OR CONNECTIONS. THE CONTRACTOR SHALL VERIFY THE ACTUAL LOCATIONS OF THE EXISTING UTILITIES FOUND IN THE FIELD ARE DIFFERENT FROM WHAT IS SHOWN ON THESE PLANS. THE CONTRACTOR SHALL CONTACT RFE ENGINEERING IMMEDIATELY AND PROVIDE THE ACTUAL LOCATION INFORMATION. RFE ENGINEERING WILL VERIFY IF THERE ARE ANY CONFLICTS WITH IMPROVEMENTS AND WILL PROVIDE MODIFICATIONS TO THE DESIGN TO MITIGATE THE CONFLICTS IF ANY CONFLICTS EXIST.

LEGEND:

BUILDING SETBACK ————BSL————BSL————BSL————

FIRE LANE STRIPING

FIRE STRIPING KEY NOTE:

① FIRE LANE DESIGNATION STRIPE AS DELINEATED ON THE DRAWINGS. CURBS SHALL BE PAINTED RED MARKED BY WHITE LETTERING "FIRE LANE - NO PARKING" A MINIMUM OF THREE INCHES TALL WITH A 1/2 INCH WIDE MINIMUM STROKE. THE INTERVAL BETWEEN STENCILED LETTERING SHALL BE ADEQUATE TO INFORM THE PUBLIC OF THE EXISTENCE OF THE FIRE LANE BUT IN NO EVENT SHALL THE INTERVAL EXCEED 50 FEET.

Ph: 916-772-7800 | www.cwecorp.com

PROPERTY OWNER / DEVELOPER
NERRADSCALI CORPORATION
3960 KINGSBARN DRIVE
ROSEVILLE, CA 95747

CONTACT: DARREN BROWN
PH: (916) 300-7962
EMAIL: DARRENBROWN@COMCAST.NET

**HORIZONTAL
CONTROL PLAN**

meet

C5


6 of 14

6/12/2023



Know what's **below**.

Call before you dig.
or (800) 227-2600



\\s\2021 Projects\21-188 905 North Ave San Jose\Working CAD\ON-SITE C6 GRADING PLAN.dwg Jun 14, 2023--03:11 pm

Grading sheet shall show existing and proposed elevations, grade breaks, finished floor elevations and overland flow release arrows; pavement information, including curbs, gutters and sidewalks; and surface stormwater quality features. Cross sections showing existing and proposed grading, fences, walls, property lines, right-of-way, easements, drainage flow arrows, utilities, dimensions, and finished pavement sections and base information.

See section 3.3 on the Onsite Design Manual on what shall be included on the Grading/Drainage Plan.

All items listed in Section 3.3 of the City of Sacramento DOU Onsite Design Manual are shown on either this sheet or C6.2.

Finished floor elevations shall be a minimum of 6-inches above the 100-year HGL or 1-foot above the overland flow release elevation.

Include the 100-YR HGL.

DOU will defer the review of the Finished Floor Elevations pending on the approval of the drainage study.

After discussion with City of Sacramento DOU, the FF will be raised to a min. 35.00 elevation.

Private reciprocal easement will allow for drainage to cross property lines. See Note A on page 10 of Attachment 3 - Final Map.

All lots shall be graded so that drainage does not cross property lines. Regraded the swales as necessary.

7,000 cubic feet of detention must be provided per each additional acre of impervious area with a limited maximum discharge rate of 0.2 cfs/acre or per the latest approved onsite criteria.

Please make sure that the proposed detention basin is size correctly.

Also please clarify how the flows are being restricted.

Per the design, the flows shall be restricted at the point of service manhole, see attached detail.

Please see Section F of the Drainage Study for discussion of detention basin sizing and outlet control.

Change the layer for the property lines to differentiate from the drainage pipe.

Property line that crosses directly over storm drain pipes is now hidden on this sheet. Note added to provide clarity.

Landscape drain inlet has been updated to: 24" Nyloplast drain basin (or approved equal). Per Lorenzo Hernandez of City of Sacramento, the City does not have a specific detail for a landscape drain inlet, so a general call out is used.

Call out the detail for this landscape drain inlet.

Use standard manhole 3A per City Standard Drawing S-80, when greater than 8-feet deep and less the 27" diameter.

Revised to Standard Drawing S-80. Detail 4 on sheet C10.2 also updated.

Drainage pipe material in private storm drain systems shall comply with the approved drainage pipe material specified in Section 26-4 of the City of Sacramento Standard Specifications, with two exceptions:

- Landscaped areas with drainage pipe less than 6-inches in diameter may use single wall corrugated drainage pipe or other approved alternative pipe material.
- Oversized drainage pipe used for detention purposes may be either high-density polyethylene (HDPE) or aluminum steel type 2 or polymer coated corrugated metal pipe (CMP).

Revise pipe material accordingly.

Pipe material revised from HDPE to PVC.

LEGEND:

- OVERLAND RELEASE
- DRAINAGE FLOW DIRECTION
- GATE AND FENCING - SEE ARCHITECTURAL PLANS
- AC DRIVE AISLE (TI=6.0)
4" HMA / 12" CL 2 AB
- HEAVY DUTY PCC (4,000 PSI)
6" PCC / 7" CL 2 AB
NO. 4 REBAR @ 12" OCEW
- PEDESTRIAN PCC (4,000 PSI)
4" PCC / 6" CL 2 AB
NO.4 REBAR @ 18" OCEW
- LANDSCAPING
SEE LANDSCAPE PLANS

GRADING CONSTRUCTION KEYNOTES:

- CONSTRUCT 6" STAMPED CONCRETE DRIVEWAY. SEE ARCHITECTURAL AND LANDSCAPE PLANS FOR PATTERN DETAILS.
- CONSTRUCT STORMWATER DETENTION / SEDIMENT POND.
- PLACE 6' HIGH SECURITY FENCE AROUND PERIMETER OF DETENTION BASIN WITH ACCESS GATE. SEE ARCHITECTURAL PLANS FOR DETAILS.
- CONSTRUCT CONCRETE DRIVEWAY.
- CONSTRUCT VEGETATED DRAINAGE SWALE AT A MIN. 1.0% SLOPE. SEE DETAIL 3, SHEET C10.2 FOR SWALE DETAILS.
- CONSTRUCT CONCRETE PATIOS, PORCH. WITH 4" PCC / 6" CLASS 2 AB. CONCRETE TO BE 4" BELOW HOUSE ELEVATION AT DOOR THRESHOLD AND 4" ABOVE ADJACENT FINISHED GRADE. CONTRACTOR TO SLOPE CONCRETE A MAXIMUM 2% AWAY FROM HOUSE.
- CONSTRUCT ON-SITE CONCRETE PEDESTRIAN SIDEWALK PER DETAIL 1, SHEET C10.2.
- CONSTRUCT DITCH BOX PER SACRAMENTO CITY STANDARD DETAIL S-30, REFERENCED ON SHEET C10.2.

STORMDRAIN CONSTRUCTION KEYNOTES:

- D1 INSTALL DRAIN INLET TYPE 1 OR APPROVED EQUAL (EXCLUDING LANDSCAPE AND DRAINAGE INLET) PER DETAIL 5, SEE SHEET C10.2.
- D2 INSTALL INLET ON 29.80 CONTOUR OF SLOPE.
- D3 INSTALL FLARED END SECTION WITH ROCK SLOPE PROTECTION PER DETAIL 7, SEE SHEET C10.2 - REF. CASQA BMP EC-10.
- D4 INSTALL STORM DRAIN MANHOLE PER SACRAMENTO CITY STANDARD DWG. NO. S-70, REFERENCED ON SHEET C10.2.

NOTES:

- ALL VALVES, MANHOLES, CLEANOUTS, D'S, ETC. WITHIN LIMITS OF CONSTRUCTION TO BE ADJUSTED TO FINISH GRADE AS NEEDED.
- SEE PAVEMENT SECTIONS ON REFERENCED ON LEGENDS.
- GRADING AND PAVING SHALL BE IN ACCORDANCE WITH PROJECT GEOTECHNICAL REPORT.
- VERIFY ALL UTILITY LOCATIONS PRIOR TO CONSTRUCTION.
- SEE SHEET C1 FOR APPROXIMATE EARTHWORK SUMMARY.
- SEE SHEET C2 FOR CITY MANDATORY GRADING NOTES.
- ALL 6", 8", AND 12" PIPING SHOWN HEREON LEADING TO LANDSCAPE DRAINS AND ROOF LEADERS SHALL BE INSTALLED AT MINIMUM SLOPES OF 1.0%, 0.50%, AND 0.35%, RESPECTIVELY.
- STRUCTURAL SECTIONS ASSUME LIME TREATED SUBGRADE PER GEOTECHNICAL REPORT. REFERENCE GEOTECHNICAL REPORT LIME TREATMENT RECOMMENDATIONS.
- PRIOR TO PLACEMENT OF PAVING/CONCRETE, UPPER 8" OF LIME TREATED SUBGRADE SOILS SHALL BE COMPACTED TO 95% RC AT OPTIMUM MOISTURE CONTENT.
- COMPACT ALL AGGREGATE BASE TO 95% RC.
- ALL PAVING/CONCRETE SHALL BE PER THE GEOTECHNICAL REPORT REFERENCED ON SHEET C1.

STORM DRAIN PIPE TABLE


PIPE#	SIZE	LENGTH	MATERIAL	BEARING	SLOPE
SD1	12"	78 LF	HDPE	N77°54'20"E	1.00%
SD2	12"	34 LF	HDPE	N07°26'29"E	1.00%
SD3	18"	33 LF	HDPE	N12°05'41"W	3.36%
SD4	12"	72 LF	HDPE	N55°37'39"W	4.98%
SD5	18"	34 LF	HDPE	S54°58'45"E	1.00%
SD6	18"	112 LF	HDPE	S12°05'35"E	1.00%
SD7	18"	71 LF	HDPE	S00°28'12"W	1.00%

CA LICENSED CIVIL ENGINEER OR LAND SURVEYOR SHALL PREPARE AND SUBMIT A GRADING CERTIFICATION LETTER TO THE CITY BUILDING INSPECTOR CERTIFYING THE PAD ELEVATIONS PRIOR TO FOOTING INSPECTION AND CERTIFYING FINAL GRADING PRIOR TO THE PROJECT'S FINAL INSPECTION.

"I HAVE COMPLIED WITH THE CRITERIA OF SACRAMENTO CITY CODE CHAPTER 15.92 AND APPLIED THEM ACCORDING FOR THE EFFICIENT USE OF WATER IN THE GRADING DESIGN PLAN."

SHAWN B. SOMERS, P.E. C80625

DATE 6/14/2023



SEE OFF-SITE PLANS RPC23-0011 UNDER SEPARATE PERMIT FOR IMPROVEMENTS IN PUBLIC RIGHT-OF-WAY.

APPROVED	BY	DATE	REVISION	CHECK	NO.	BY	DATE	DESIGN	DRAWN	QUANT.	ORIGINAL SCALE IS IN INCHES
											0 1 2

PROPERTY OWNER / DEVELOPER
NERRASCALI CORPORATION
3960 KINGSBARN DRIVE
ROSEVILLE, CA 95747
CONTACT: DAPREN BROWN
PH: (916) 300-7962
EMAIL: DAPRENBROWN@COMCAST.NET


ON-SITE IMPROVEMENT PLANS FOR
NERRASCALI SUBDIVISION
SACRAMENTO, CA 95838
APN: 237-0200-092


GRADING, DRAINAGE
AND PAVING PLAN

Sheet
C6.1
7 of 14
6/12/2023


PROJECT NO. 21-188 - 1905 NORTH AVENUE, SACRAMENTO, CA 95838

Private reciprocal easement will allow for drainage to cross property lines. See Note A on page 10 of Attachment 3 - Final Map.



6/12/2023	8 of 14	Sheet C6.2	ON-SITE IMPROVEMENT PLANS FOR NERRADSCALI SUBDIVISION SACRAMENTO, CA 956838 APN: 237-0200-092	PROPERTY OWNER / DEVELOPER NERRADSCALI CORPORATION 3960 KINGSBERRY DRIVE ROSEVILLE, CA 95747 CONTACT: DARREN BROWN MOBILE: 916-772-1800 EMAIL: DARBROWN@COMCAST.NET	 2260 Douglas Blvd, Suite 160, Roseville, CA 95681 Ph. 916-772-1800 www.cwecorp.com		<table><tr><th>DESIGN</th><th>MJW</th><th>RFE</th></tr><tr><td>DRAWN</td><td>DCJ</td><td></td></tr><tr><td>QUANT.</td><td></td><td></td></tr></table> <table><tr><th>BY</th><th>CHECK</th><th>NO.</th><th>REVISION</th><th>DATE</th><th>BY</th><th>APPROV'D</th></tr><tr><td>0</td><td>1</td><td>1</td><td></td><td></td><td></td><td></td></tr><tr><td></td><td>2</td><td></td><td></td><td></td><td></td><td></td></tr></table>	DESIGN	MJW	RFE	DRAWN	DCJ		QUANT.			BY	CHECK	NO.	REVISION	DATE	BY	APPROV'D	0	1	1						2					
DESIGN	MJW	RFE																																			
DRAWN	DCJ																																				
QUANT.																																					
BY	CHECK	NO.	REVISION	DATE	BY	APPROV'D																															
0	1	1																																			
	2																																				

\\A\2021 Projects\21-188 905 North Ave San Working CAD\ON SITE C7 UTILITY.dwg Jun 14, 2023-03:11 pm




1
-
DETAIL
SCALE: 1" = 10'

Lorenzo Hernandez of the City of Sacramento is in the process of drafting the common water service agreement.

Private reciprocal easement for water facilities referenced, see Note A on page 10 of Attachment 3 - Final Map.

A common water service agreement will be required for the proposed common water line. In addition, an easement for the water meter and access easement is required for the Department of Utilities maintain the water meters.

Provide an update on the easement for the water meters. If the easement is going to be dedicated with final map, make sure that it is reflected on the map.



Note W3 calls out for a 1" service, however, the plans shows a 1.5", confirm the correct size.

Plans updated to show 1" service on both plans and keynotes

Provide rim elevation.

Provided

Relocate call out W2 here.

Relocated

SEE OFF-SITE PLANS RPC23-0011 UNDER SEPARATE PERMIT FOR IMPROVEMENTS IN PUBLIC RIGHT-OF-WAY.

WATER CONSTRUCTION KEYNOTES:

- W1 CONNECT TO EXISTING 6" WATER STUB AT RIGHT-OF-WAY. SEE OFF-SITE PLANS UNDER SEPARATE PERMIT FOR WATER CONNECTION IN PUBLIC RIGHT-OF-WAY.
- W2 INSTALL 6" GATE VALVES PER SACRAMENTO CITY STANDARD DETAILS W-303 AND W-304, REFERENCED ON SHEET C10.1.
- W3 INSTALL 1" RESIDENTIAL WATER SERVICE WITH METER BOX, METER SETTER, AND ALL ASSOCIATED FITTING PER CITY OF SACRAMENTO STANDARD DETAILS W-402 AND W-405, REFERENCED ON SHEET C10.1. WATER METERS TO BE INSTALLED AND WATER DEVELOPMENT FEE TO BE COLLECTED WITH ON-SITE BUILDING PERMIT FOR EACH RESIDENCE.
- W4 INSTALL 90 DEG BEND WITH THRUST BLOCKING PER CITY OF SACRAMENTO STANDARD DETAILS W-103, REFERENCED ON SHEET C10.1.
- W5 INSTALL 2" BLOW-OFF VALVE ASSEMBLY PER CITY OF SACRAMENTO STANDARD DETAIL W-301, REFERENCED ON SHEET C10.1.
- W6 PROVIDE A MIN. OF 12" VERTICAL SEPARATION BETWEEN CROSSING UTILITY PIPES.

SANITARY SEWER CONSTRUCTION KEYNOTES:

- S1 CONNECT TO EXISTING SANITARY SEWER 48" MANHOLE. SEE OFF-SITE PLANS FOR CONNECTION DETAILS.
- S2 PROVIDE 4" LATERAL SEWER SERVICE CONNECTION WITH LONG SWEEP WYE FITTING.
- S3 SANITARY SEWER POINT OF CONNECTION WITH 2-WAY CLEANOUT PER CITY OF SACRAMENTO STANDARD DETAIL S-260 AND S-265, REFERENCED ON SHEET C10.3. VERIFY CONNECTION WITH PLUMBING AND ARCHITECTURAL PLANS.
- S4 PLACE 48" SANITARY SEWER STANDARD MANHOLE NO.3 PER CITY OF SACRAMENTO STANDARD DETAIL S-70, REFERENCED ON SHEET C10.2.
- S5 PLACE 1-WAY CLEANOUT FLUSHING BRANCH.
- S6 PROVIDE A MIN. OF 12" VERTICAL SEPARATION BETWEEN CROSSING UTILITY PIPES.


NOTES:

- ALL ON-SITE WATER AND SEWER IS PRIVATE.
- STUB UTILITIES 5' FROM BUILDING.
- VERIFY HORIZONTAL AND VERTICAL LOCATION OF WATER AND SANITARY SEWER.
- CONNECTIONS AT BUILDING POCS WITH PLUMBING PLANS PRIOR TO CONSTRUCTION.
- SEE LANDSCAPE AND IRRIGATION PLANS FOR CONTINUATION OF IRRIGATION LINES.
- SEE GRADING PLANS FOR DETAILS ON STORM DRAIN LINES.
- THRUST BLOCKS FOR WATERLINES SHALL BE PER CITY STANDARD DRAWING W-103, SHEET C10.1.
- 6" WATERLINES SHALL BE PVC C-900 CL 150 OR APPROVED EQUAL UNLESS OTHERWISE SHOWN.
- BEDDING, INITIAL AND TRENCH BACKFILL FOR WATER SHALL BE CONSTRUCTED PER CITY STANDARD SD-16 AND THE CITY SPECIFICATIONS.
- PIPE BEDDING FOR SANITARY SEWER SHALL BE PER COUNTY STD. DWG. 7-4, SHEET C10.3.
- STREET LIGHTS SHOWN FOR REFERENCE ONLY. VERIFY LOCATIONS WITH SITE LIGHTING PLANS.

STREET LIGHT NOTE:

- ALL ON-SITE STREET LIGHTS INCLUDING POWER WILL BE PRIVATE.

SANITARY SEWER PIPE TABLE				
PIPE #	SIZE	LENGTH	MATERIAL	SLOPE
SS1	6"	23 LF	SDR-35 PVC	1.00%
SS2	6"	25 LF	SDR-35 PVC	1.00%
SS3	6"	36 LF	SDR-35 PVC	1.00%
SS4	6"	8 LF	SDR-35 PVC	1.00%
SS5	6"	85 LF	SDR-35 PVC	1.00%
SS6	6"	79 LF	SDR-35 PVC	1.00%
SS7	6"	1 LF	SDR-35 PVC	1.00%
SS8	6"	51 LF	SDR-35 PVC	1.00%
SS9	6"	1 LF	SDR-35 PVC	1.00%
SS10	6"	3 LF	SDR-35 PVC	1.00%
SS11	4"	9 LF	SDR-35 PVC	1.00%
SS12	4"	9 LF	SDR-35 PVC	1.00%
SS13	4"	15 LF	SDR-35 PVC	1.44%
SS14	4"	5 LF	SDR-35 PVC	1.45%
SS15	4"	15 LF	SDR-35 PVC	5.94%
SS16	4"	5 LF	SDR-35 PVC	1.24%
SS17	4"	25 LF	SDR-35 PVC	2.42%



NOTE:
ALL CONSTRUCTION WITHIN PUBLIC RIGHT OF WAY AND WITHIN P.U.E. SHALL HAVE ENCROACHMENT PERMIT FROM DEPT. OF TRANSPORTATION - DEV. ENGINEERING.



Call before you dig.
or (800) 227-2600

APPROVED
No. C-80625
Exp. 3-31-24
6/14/2023
CIVIL
STATE OF CALIFORNIA





2280 Douglas Blvd, Suite 100, Roseville, CA 95661
PH: 916-772-7800 | www.cwecorp.com


PROPERTY OWNER / DEVELOPER
NERRASCALI CORPORATION
3960 KINGSBARY DRIVE
ROSEVILLE, CA 95747
CONTACT: DAPHNE BROWN
PH: (916) 300-7962
EMAIL: DARRENBROWN@COMCAST.NET

ON-SITE IMPROVEMENT PLANS FOR
NERRASCALI SUBDIVISION
SACRAMENTO, CA 95638
APN: 237-0200-092
UTILITY PLAN

Sheet
C7
9 of 14
6/12/2023

APPROVED
BY
DATE
REVISION
NO.
BY
CHECK
NO.
BY
DESIGN
DRAWN
QUANT.
ORIGINAL SCALE IS IN INCHES
2
1
0



- | | |
|--|---|
| FIBER ROLL |  |
| SURFACE FLOW |  |
| GRAVEL BAG AND INLET FILTER |  |
| TEMPORARY STABILIZED CONSTRUCTION ENTRANCE |  |
| OVERLAND RELEASE |  |
| CULVERT CHECK DAM |  |
| CONCRETE WASHOUT |  |

1. THE CONTRACTOR SHALL FOLLOW THE GUIDELINES FOR THE CITY OF SACRAMENTO'S "ADMINISTRATIVE AND TECHNICAL PROCEDURES MANUAL FOR GRADING AND EROSION AND SEDIMENT CONTROL" FOR THE MEASURES SHOWN OR STATED ON THESE PLANS.
2. CONTRACTOR MUST ENSURE THAT THE CONSTRUCTION SITE IS PREPARED PRIOR TO THE ONSET OF ANY STORM. CONTRACTOR SHALL HAVE ALL EROSION AND SEDIMENT CONTROL MEASURES IN PLACE FOR THE WINTER MONTHS PRIOR TO OCTOBER 1.
3. ALL EROSION AND SEDIMENT CONTROL MEASURES SHALL BE MAINTAINED UNTIL DISTURBED AREAS ARE STABILIZED. CHANGES TO THIS EROSION AND SEDIMENT CONTROL PLAN SHALL BE MADE TO MEET FIELD CONDITIONS ONLY WITH THE APPROVAL OF OR AT THE DIRECTION OF A REPRESENTATIVE OF THE DEPARTMENT OF UTILITIES.
4. THIS PLAN MAY NOT COVER ALL THE SITUATIONS THAT ARISE DURING CONSTRUCTION DUE TO UNANTICIPATED FIELD CONDITIONS. VARIATIONS MAY BE MADE TO THE PLAN IN THE FIELD SUBJECT TO THE APPROVAL OF OR AT THE DIRECTION OF A REPRESENTATIVE OF THE DEPARTMENT OF UTILITIES.
5. ALL EROSION AND SEDIMENT CONTROL MEASURES SHALL BE CHECKED BEFORE AND AFTER ALL STORMS TO ENSURE MEASURES ARE FUNCTIONING PROPERLY.
6. CONTRACTOR SHALL MAINTAIN A LOG AT THE SITE OF ALL INSPECTIONS OR MAINTENANCE OF BMPs AS WELL AS, ANY CORRECTIVE CHANGES TO THE BMPs OR EROSION AND SEDIMENT CONTROL PLAN.
7. IN AREAS WHERE SOIL IS EXPOSED, PROMPT REPLANTING WITH NATIVE COMPATIBLE, DROUGHT-RESISTANT VEGETATION SHALL BE PERFORMED. NO AREAS WILL BE LEFT EXPOSED OVER THE WINTER SEASON.
8. THE CONTRACTOR SHALL INSTALL THE STABILIZED CONSTRUCTION ENTRANCE PRIOR TO COMMENCEMENT OF GRADING. LOCATION OF THE ENTRANCE MAY BE ADJUSTED BY THE CONTRACTOR TO FACILITATE GRADING OPERATIONS. ALL CONSTRUCTION TRAFFIC ENTERING THE PAVED ROAD MUST CROSS THE STABILIZED CONSTRUCTION ENTRANCE. THE STABILIZED CONSTRUCTION ENTRANCE SHALL REMAIN IN PLACE UNTIL THE ROAD BASE ROCK COURSE IS COMPLETED.
9. ALL SEDIMENT DEPOSITED ON PAVED ROADWAYS SHALL BE SWEEPED AT THE END OF EACH WORKING DAY OR AS NECESSARY.
10. CONTRACTOR SHALL PLACE AROUND ALL NEW DRAINAGE STRUCTURE OPENINGS IMMEDIATELY AFTER THE STRUCTURE OPENING IS CONSTRUCTED. THESE SHALL BE MAINTAINED AND REMAIN IN PLACE UNTIL CONSTRUCTION IS COMPLETED.
11. CONTRACTOR SHALL IMPLEMENT HOUSEKEEPING PRACTICES AS FOLLOWS:
 - A. SOLID WASTE MANAGEMENT:
PROVIDE DESIGNATED WASTE COLLECTION AREAS AND CONTAINERS. ARRANGE FOR REGULAR REMOVAL AND DISPOSAL. CLEAR SITE OF TRASH INCLUDING ORGANIC DEBRIS, PACKAGING MATERIALS, SCRAP OR SURPLUS BUILDING MATERIALS AND DOMESTIC WASTE DAILY.
 - B. MATERIAL DELIVERY AND STORAGE:
PROVIDE A DESIGNATED MATERIAL STORAGE AREA WITH SECONDARY CONTAINMENT SUCH AS BERMING. STORE MATERIAL ON PALLETS AND PROVIDE COVERING FOR SOLUBLE MATERIALS. RELOCATE STORAGE AREA INTO BUILDING SHELL WHEN POSSIBLE. INSPECT AREA WEEKLY.
 - C. CONCRETE WASTE:
PROVIDE A DESIGNATED AREA FOR A TEMPORARY PIT TO BE USED FOR CONCRETE TRUCK WASH-OUT. DISPOSE OF HARDENED CONCRETE OFFSITE. AT NO TIME SHALL A CONCRETE TRUCK DUMP ITS WASTE AND CLEAN ITS TRUCK INTO THE CITY STORM DRAINS VIA CURB AND GUTTER. INSPECT DAILY TO CONTROL RUNOFF, AND WEEKLY FOR REMOVAL OF HARDENED CONCRETE.
 - D. PAINT AND PAINTING SUPPLIES:
PROVIDE INSTRUCTION TO EMPLOYEES AND SUBCONTRACTORS REGARDING REDUCTION OF POLLUTANTS INCLUDING MATERIAL STORAGE, USE, AND CLEAN UP. INSPECT SITE WEEKLY FOR EVIDENCE OF IMPROPER DISPOSAL.
 - E. VEHICLE FUELING, MAINTENANCE AND CLEANING:
PROVIDE A DESIGNATED FUELING AREA WITH SECONDARY CONTAINMENT SUCH AS BERMING. DO NOT ALLOW MOBILE FUELING OF EQUIPMENT. PROVIDE EQUIPMENT WITH DRIP PANS. RESTRICT ONSITE MAINTENANCE AND CLEANING OF EQUIPMENT TO A MINIMUM. INSPECT AREA WEEKLY.
 - F. HAZARDOUS WASTE MANAGEMENT:
PREVENT THE DISCHARGE OF POLLUTANTS FROM HAZARDOUS WASTES TO THE DRAINAGE SYSTEM THROUGH PROPER MATERIAL USE, WASTE DISPOSAL AND TRAINING OF EMPLOYEES. HAZARDOUS WASTE PRODUCTS COMMONLY FOUND ON-SITE INCLUDE BUT ARE NOT LIMITED TO PAINTS & SOLVENTS, PETROLEUM PRODUCTS, FERTILIZERS, HERBICIDES & PESTICIDES, SOIL STABILIZATION PRODUCTS, ASPHALT PRODUCTS AND CONCRETE CURING PRODUCTS.

- ① PLACE FIBER ROLL AT TOP BACK OF WALK AND TOP BACK OF CURB PER CITY OF SACRAMENTO STD DWG Q-40, SHEET C9.
- ② INSTALL STORM DRAIN SEDIMENT BARRIER AND INLET FILTER PER CITY OF SACRAMENTO STD DWG Q-20 AND Q-30, SHEET C9.
- ③ INSTALL TEMPORARY STABILIZED CONSTRUCTION ENTRANCE PER CITY OF SACRAMENTO STD DWG Q-10, SHEET C9.
- ④ CONCRETE WASHOUT PER DETAIL 2, SEE SHEET C9 - REF. CASQA BMP WM-8.
- ⑤ PLACE PORTABLE TOILET FOR USE DURING CONSTRUCTION. ANCHOR TO PREVENT OVERTURNING - REF. CASQA BMP WM-9.
- ⑥ INSTALL TEMPORARY 6' HIGH CHAINLINK SECURITY FENCE.
- ⑦ STAGING AREA, MATERIAL STORAGE, TEMPORARY STOCKPILE STORAGE AREA, FUELING AREA.
- ⑧ PLACE TEMPORARY CULVERT EROSION SEDIMENT CHECK DAM PER DETAIL 1, ON SHEET C9.

THE CONTRACTOR SHALL COMPLY WITH THE CITY OF SACRAMENTO ADMINISTRATIVE AND TECHNICAL MANUAL FOR GRADING/EROSION AND SEDIMENT CONTROL. CONTRACTOR SHALL HAVE ALL APPROPRIATE EROSION AND SEDIMENT CONTROL MEASURES IN PLACE FOR THE WINTER MONTHS PRIOR TO OCTOBER 1ST AND MUST ENSURE THAT THE CONSTRUCTION SITE IS PREPARED FOR THE ONSET OF ANY STORM.



Know what's **below**.
Call before you dig
 or (800) 227-2600

6/12/2023	10 of 14	Sheet C8	ON-SITE IMPROVEMENT PLANS FOR NERRADSCALI SUBDIVISION SACRAMENTO, CA 95838 APN: 237-0200-092	PROPERTY OWNER / DEVELOPER NERRADSCALI CORPORATION 3960 KINGSBARN DRIVE ROSEVILLE, CA 95747 CONTACT: DARREN BROWN PH: (916) 300-7962 EMAIL: DARRENBROWN@COMCAST.NET	 2260 Douglas Blvd. Suite 160, Roseville, CA 95661 Ph: 916-772-7800 www.cwecorp.com		<table><tr><th rowspan="2">NO.</th><th colspan="2">CHECK</th><th rowspan="2">DATE</th><th rowspan="2">BY</th><th rowspan="2">APPROV'D</th></tr><tr><th>BY</th><th>RFE</th></tr><tr><td></td><td>DESIGN</td><td>MJM</td><td></td><td></td><td></td></tr><tr><td></td><td>DRAWN</td><td>DCJ</td><td></td><td></td><td></td></tr><tr><td></td><td colspan="2">QUANT.</td><td></td><td></td><td></td></tr></table> ORIGINAL SCALE IS IN INCHES 0 1 2	NO.	CHECK		DATE	BY	APPROV'D	BY	RFE		DESIGN	MJM					DRAWN	DCJ					QUANT.				
NO.	CHECK		DATE	BY	APPROV'D																												
	BY	RFE																															
	DESIGN	MJM																															
	DRAWN	DCJ																															
	QUANT.																																

EROSION AND SEDIMENT CONTROL NOTES:

1. THE CONTRACTOR SHALL FOLLOW ALL JURISDICTIONAL GUIDELINES FOR GRADING AND THE EROSION AND SEDIMENT CONTROL MEASURES SHOWN OR STATED ON THESE PLANS.

2. CONTRACTOR MUST ENSURE THAT THE CONSTRUCTION SITE IS PREPARED PRIOR TO THE ONSET OF ANY STORM. CONTRACTOR SHALL HAVE ALL EROSION AND SEDIMENT CONTROL MEASURES IN PLACE FOR THE WINTER MONTHS PRIOR TO OCTOBER 1.

3. ALL EROSION AND SEDIMENT CONTROL MEASURES SHALL BE MAINTAINED UNTIL DISTURBED AREAS ARE STABILIZED. CHANGES TO THIS EROSION AND SEDIMENT CONTROL PLAN SHALL BE MADE TO MEET FIELD CONDITIONS ONLY WITH THE APPROVAL OF OR AT THE DIRECTION OF A REPRESENTATIVE OF THE DEPARTMENT OF UTILITIES.

4. THIS PLAN MAY NOT COVER ALL THE SITUATIONS THAT ARISE DURING CONSTRUCTION DUE TO UNANTICIPATED FIELD CONDITIONS. VARIATIONS MAY BE MADE TO THE PLAN IN THE FIELD SUBJECT TO THE APPROVAL OF OR AT THE DIRECTION OF A REPRESENTATIVE OF THE DEPARTMENT OF UTILITIES.

5. ALL EROSION AND SEDIMENT CONTROL MEASURES SHALL BE CHECKED BEFORE AND AFTER ALL STORMS TO ENSURE MEASURES ARE FUNCTIONING PROPERLY.

6. CONTRACTOR SHALL MAINTAIN A LOG AT THE SITE OF ALL INSPECTIONS OR MAINTENANCE OF BMPs, AS WELL AS, ANY CORRECTIVE CHANGES TO THE BMPs OR EROSION AND SEDIMENT CONTROL PLAN.

7. IN AREAS WHERE SOIL IS EXPOSED, PROMPT REPLANTING WITH NATIVE COMPATIBLE, DROUGHT-RESISTANT VEGETATION SHALL BE PERFORMED. NO AREAS WILL BE LEFT EXPOSED OVER THE WINTER SEASON.

8. THE CONTRACTOR SHALL INSTALL THE STABILIZED CONSTRUCTION ENTRANCE PRIOR TO COMMENCEMENT OF GRADING. LOCATION OF THE ENTRANCE MAY BE ADJUSTED BY THE CONTRACTOR TO FACILITATE GRADING OPERATIONS. ALL CONSTRUCTION TRAFFIC ENTERING THE PAVED ROAD MUST CROSS THE STABILIZED CONSTRUCTION ENTRANCE. THE STABILIZED CONSTRUCTION ENTRANCE SHALL REMAIN IN PLACE UNTIL THE ROAD BASE ROCK COURSE IS COMPLETED.


9. ALL SEDIMENT DEPOSITED ON PAVED ROADWAYS SHALL BE SWEEPED AT THE END OF EACH WORKING DAY OR AS NECESSARY.

10. CONTRACTOR SHALL PLACE GRAVEL BAG BARRIERS AROUND ALL NEW DRAINAGE STRUCTURE OPENINGS IMMEDIATELY AFTER THE STRUCTURE OPENING IS CONSTRUCTED. THESE GRAVEL BAG BARRIERS SHALL BE MAINTAINED AND REMAIN IN PLACE UNTIL CONSTRUCTION IS COMPLETED.
11. CONTRACTOR SHALL FOLLOW DUST CONTROL METHODS INCLUDING:
A. WATERING THE SOIL OF THE SITE AND THE ADJACENT STREETS BEING USED IN CONNECTION WITH SOIL DISTURBANCE OPERATIONS ON THE SITE.
B. COMPLETELY COVER GRAVEL OR ROCK LANDSCAPING UNTIL STABILIZED.
D. WATER GRASSES AND LANDSCAPING UNTIL STABILIZED.


12. CONTRACTOR SHALL IMPLEMENT HOUSEKEEPING PRACTICES AS FOLLOWS:
A. SOLID WASTE MANAGEMENT:
PROVIDE DESIGNATED WASTE COLLECTION AREAS AND CONTAINERS. ARRANGE FOR REGULAR REMOVAL AND DISPOSAL. CLEAR SITE OF TRASH INCLUDING ORGANIC DEBRIS, PACKAGING MATERIALS, SCRAP OR SURPLUS BUILDING MATERIALS AND DOMESTIC WASTE DAILY.
B. MATERIAL DELIVERY AND STORAGE:
PROVIDE A DESIGNATED MATERIAL STORAGE AREA WITH SECONDARY CONTAINMENT SUCH AS BERMING. STORE MATERIAL ON PALLETS AND PROVIDE COVERING FOR SOLUBLE MATERIALS. RELOCATE STORAGE AREA INTO BUILDING SHELL WHEN POSSIBLE. INSPECT AREA WEEKLY.
C. CONCRETE WASTE:
PROVIDE A DESIGNATED AREA FOR A TEMPORARY PIT TO BE USED FOR CONCRETE TRUCK WASH-OUT. DISPOSE OF HARDENED CONCRETE OFFSITE. AT NO TIME SHALL A CONCRETE TRUCK DUMP ITS WASTE AND CLEAN ITS TRUCK INTO THE CITY STORM DRAINS VIA CURB AND GUTTER. INSPECT DAILY TO CONTROL RUNOFF, AND WEEKLY FOR REMOVAL OF HARDENED CONCRETE.
D. PAINT AND PAINTING SUPPLIES:
PROVIDE INSTRUCTION TO EMPLOYEES AND SUBCONTRACTORS REGARDING REDUCTION OF POLLUTANTS INCLUDING MATERIAL STORAGE, USE, AND CLEAN UP. INSPECT SITE WEEKLY FOR EVIDENCE OF IMPROPER DISPOSAL.
E. VEHICLE FUELING, MAINTENANCE AND CLEANING:
PROVIDE A DESIGNATED FUELING AREA WITH SECONDARY CONTAINMENT SUCH AS BERMING. DO NOT ALLOW MOBILE FUELING OF EQUIPMENT. PROVIDE EQUIPMENT WITH DRIP PANS. RESTRICT ON-SITE MAINTENANCE AND CLEANING OF EQUIPMENT TO A MINIMUM. INSPECT AREA WEEKLY.
F. HAZARDOUS WASTE MANAGEMENT:
PREVENT THE DISCHARGE OF POLLUTANTS FROM HAZARDOUS WASTES TO THE DRAINAGE SYSTEM THROUGH PROPER MATERIAL USE, WASTE DISPOSAL AND TRAINING OF EMPLOYEES. HAZARDOUS WASTE PRODUCTS COMMONLY FOUND ON-SITE INCLUDE BUT ARE NOT LIMITED TO PAINTS & SOLVENTS, PETROLEUM PRODUCTS, FERTILIZERS, HERBICIDES & PESTICIDES, SOIL STABILIZATION STABILIZATION PRODUCTS, ASPHALT PRODUCTS AND CONCRETE CURING PRODUCTS.

PHASE OF CONSTRUCTION	EROSION AND SEDIMENT CONTROL MEASURES												
	(WET SEASON)					(WET AND DRY SEASON)							
	HYDRO-SEEDING	STRAW MULCHING & TACTIFIER	PRESERVATION OF EXISTING VEGETATION	SOIL BINDERS	FIBER ROLLS	OUTLET PROTECTION	STORM DRAIN INLET PROTECTION	DEWATERING	STABILIZED CONSTRUCTION ENTRANCE	MATERIAL & WASTE DISPOSAL LOCATION	CONCRETE WASHOUT	DUST CONTROL	SEDIMENT TRAP
PRE-GRADING			●		●		●		●	●		●	●
CUT AND FILL ACTIVITIES	●	●		●				●				●	●
UNDERGROUND WORK												●	
STORM DRAIN IMPROVEMENTS						●					●	●	
CURB & GUTTER							●					●	
STREET IMPROVEMENTS					●							●	
POST CONSTRUCTION	●	●	●										


NOTES:
1. ALL EROSION BMPs SHALL BE IN PLACE PRIOR TO STORM EVENTS AND IN ACCORDANCE WITH THE LATEST EDITION OF SECTION II OF THE IMPROVEMENT STANDARDS AND THE CALIFORNIA STORM WATER HANDBOOK.
2. MAINTAIN BMPs AS NECESSARY.




\\sac\2021 Projects\21-188 905 North Ave San Working CAD\CONSTR CIO & CIO1 CONST DTL S.dwg Jun 14, 2023 3:03:12 pm




4 NTS MANHOLE DETAIL




3 NTS VEGETATED SWALE DETAIL




2 NTS PAVEMENT MARKINGS FOR FIRE LANES




1 NTS CONCRETE WALK WITH JOINT SPACING




8 NTS TRENCH AND BACKFILL DETAIL



7 NTS FLARED END SECTION WITH ROCK SLOPE PROTECTION



6 NTS DITCH BOX



5 NTS DRAIN INLET (TYPE 1) DETAIL

4 NTS MANHOLE DETAIL

3 NTS VEGETATED SWALE DETAIL

2 NTS PAVEMENT MARKINGS FOR FIRE LANES

1 NTS CONCRETE WALK WITH JOINT SPACING

APPROVED	BY	DATE	REVISION	CHECK	NO.	BY	DATE	DESIGN	DRAWN	QUANT.	ORIGINAL SCALE IS IN INCHES
											2
											1
											0

REGISTERED PROFESSIONAL ENGINEER
No. C-80625
Exp. 6-31-25
6/14/2023
STATE OF CALIFORNIA
CIVIL

PROPERTY OWNER / DEVELOPER
NERRASCALI CORPORATION
3960 KINGSBARN DRIVE
ROSEVILLE, CA 95747
CONTACT: DAPREN BROWN
PH: (916) 300-7962
EMAIL: DAPRENBROWN@COMCAST.NET

ON-SITE IMPROVEMENT PLANS FOR NERRASCALI SUBDIVISION
SACRAMENTO, CA 95638
APN: 237-0200-092

CONSTRUCTION DETAILS 2

Sheet
C10.2
13 of 14
6/12/2023



The study used Autodesk Hydraflow to calculate the HGL, when the project is supposed to use an excel spreadsheet or hand calculations using Mannings Equation so the Department of Utilities (DOU) can check the work. DOU does have a hydraflow software to verify the results.

Revise the study to meet City standards, see section 3.1 on the Onsite Design Manual, see link below:

<https://www.cityofsacramento.org/-/media/Corporate/Files/DOU/Specs-Drawings/OnsiteDesignManual.pdf?la=en>


The 10-year HGL was recalculated using Manning's equation. A narrative describing the process can be found in Section F on pages 8-9.

DRAINAGE STUDY FOR 222 NORTH AVENUE

An onsite drainage study shall include the following (at a minimum):

- A written description of the project.
- Reference to the City drainage basin that contains the project and regional study if applicable.
- Elevation datum used in study and for all referenced information.
- 10 and 100-year event tailwater elevations and sources.
- Summary of proposed drainage improvements.
- Attached excerpts of studies and other information that may be referenced.
- Summary of the methods used for the drainage study.
- Copies of calculations, spread sheets or computer models.
- An exhibit that:
 - * Depicts existing and proposed impervious areas.
 - * Shows proposed detention methods and locations including the volume of storage provided.
 - * Depicts the onsite drainage system and connection points to the City system; including drainage inlet and manhole locations; and pipe lengths, sizes, slopes and invert elevations.
 - * Denotes the elevation and location of the controlling overland release point(s) on the City drainage system. See Section 11.1.3 of the DPM for a definition of overland release point.
 - * Depicts onsite drainage shed areas, includes overland release arrows to the public right-of-way and calls out drainage shed breakpoint elevations.

- See section C
- Referenced on page 9
- See section A
- See section F
- See section F
- See Appendix C
- See section F
- See Appendix D
- See Appendix B



Prepared by,
CWE-RFE
1234567890 Blvd., Suite 160
Sacramento, CA 95661

Ph 916-772-7800

CWE-RFE Project No. 21-188

Make sure that the study matches the latest onsite plans.

Most up-to-date onsite plans are referenced in this revised study



TABLE OF CONTENTS

A.	PROJECT LOCATION.....	4
B.	EXISTING SITE CONDITIONS	4
	<i>Table 1: Site Description (Surrounding Areas).....</i>	<i>4</i>
C.	PROPOSED PROJECT DESCRIPTION.....	5
D.	PURPOSE OF REPORT	5
E.	EXISTING STORM DRAINAGE CONDITIONS	6
	<i>Table 1: Existing Shed Summary</i>	<i>6</i>
F.	POST-CONSTRUCTION STORM DRAINAGE CONDITIONS	7
	<i>Onsite Project Storage.....</i>	<i>7</i>
	<i>Table 2: Required Detention Volume.....</i>	<i>7</i>
	<i>Onsite Hydraulic Analysis and Overland Release.....</i>	<i>8</i>
	<i>Table 3: 10-YR Design Flows.....</i>	<i>8</i>
	<i>Table 4: 10-YR HGL Analysis</i>	<i>9</i>
G.	STORMWATER QUALITY EVALUATION	9
	<i>Table 5: Post-Construction Source Control Measures</i>	<i>9</i>
H.	CONCLUSIONS	10
I.	RECOMMENDATIONS	10
J.	REFERENCES.....	11



APPENDIX

APPENDIX A	VICINITY MAP AND SITE PLAN EXHIBITS
APPENDIX B	PROJECT SITE SHED MAPS AND OTHER SITE EXHIBITS
APPENDIX C	MISCELLANEOUS DOCUMENTATION
APPENDIX D	SUPPORTING CALCULATIONS

A. PROJECT LOCATION

The proposed residential grading, drainage, and utilities project is located east of the intersection of North Avenue and Rio Linda Boulevard, just south of Interstate 80 in the City of Sacramento, State of California, 95838. The approximate coordinates of the project site are latitude 38.640581° north and longitude -121.445747° west. The project property is about 1.41 acres and has APN 237-0200-092. Approximately 1.32 acres will be disturbed as part of this project, which includes off-site improvements encompassing the widening of North Avenue. The project's location is shown on the Vicinity Map in Appendix A.

B. EXISTING SITE CONDITIONS

In its existing condition, the site is partially developed with a house on-site with driveway access to North Avenue. Additionally, there are two wooden sheds and one metal shed north of the existing house. There is an electrical transmission tower located at the northeast corner of the property which includes a 100-foot-wide easement that encumbers a portion of the eastern part of the site. The southern property line extends 20 feet beyond the existing right-of-way, and there is rolled curb, gutter, and sidewalk along the project frontage, between the City right-of-way and the southern property line. The remainder of the site is undeveloped and contains a fair number of trees and short, dead grass. The site slopes consistently from southwest to northeast, and it is expected that the most incident rainfall is infiltrated, with some surface flow terminating into the City-owned concrete channel north of the property. These slope of the ground is moderate (between 2-5%).

There is no existing on-site drainage infrastructure, and most rainfall is either infiltrated or discharged by surface runoff. The frontage curb, gutter, and sidewalk produce the only runoff to the south, which is conveyed by existing City-owned underground pipes. Existing drainage patterns are further discussed in section E of this report. The property is located within Zone "X", indicating the site is outside the 0.2 annual chance flood plain as determined by the national flood insurance program according to Map number: 06067C0064 dated: June 16, 2015. The Pre-construction Shed Map, SM1, in Appendix B shows existing conditions on the project site.

Table 1 below summarizes the surrounding properties.

Table 1: Site Description (Surrounding Areas)

North	City-owned concrete channel, beyond which is Interstate 80
South	North Avenue, beyond which are residential properties
East	North Avenue Apartments
West	Residential property

Geotechnical Findings

A geotechnical investigation was performed by Allerion Consulting Group on March 23, 2022 and discovered the following information.

The site was generally consistent in subsurface earth material and the uppermost soils to a depth of approximately 1.5 feet consisted of medium stiff, moist, dark brown, sandy silt, with occasional gravel. Underlying the silt was discovered stiff to very stiff, moist, light brown and dark brown, sandy silty clay to varying depths between 2.5 to 3 feet. The material encountered below the upper soil to a depth of approximately 13 feet consisted of very stiff and hard, moist, light brown with orange mottles and red-brown, sandy silt. Below this consisted of dense, moist, dark brown to brown, SAND to a depth of approximately 19 feet.

Groundwater was not encountered within any of the exploratory borings.

C. PROPOSED PROJECT DESCRIPTION

This project proposes to improve the site by subdividing the property into 8 lots and constructing residential structures on each lot (except the lot with the existing house). Additionally, a private access drive, easement, and adjacent pedestrian sidewalk will be constructed to provide access and fire protection to the landlocked lots. North avenue will be widened to the standard 35.5' half width right-of-way of a minor collector per City of Sacramento standards. This will include additional paving and rolled curb, gutter, and detached sidewalk within the expanded public right-of-way. The existing house lot and one other lot will have direct access to North Avenue, while the remaining lots will connect to the private access drive, which will have driveway access to North Avenue at the corner of the property. In addition to the aforementioned improvements, the project will include stormwater piping and underground water, sanitary sewer, and drainage infrastructure.

The project will also add an on-site private detention basin that will serve to detain stormwater and provide flood control for the site. The site aims to maintain existing drainage infrastructure along the public sidewalk to North Avenue and convey the remainder of the site to the detention basin at the north of the property, eventually discharging into the concrete-lined channel beyond the north property line. See section F for an in-depth discussion of the proposed storm drainage improvements. Other underground infrastructure will include private water and sanitary sewer lines, as well as minimal storm drain piping to convey flows to the basin.

The total area to be disturbed will be approximately 1.32 acres. The Site plan in Appendix A shows the proposed site and the Post-Construction Shed Map, SM2, in Appendix B shows proposed site grading.

D. PURPOSE OF REPORT

The purpose of this report is to present the design of the storm drainage system and to demonstrate that the design complies with the City of Sacramento Design and Procedures Manual, the City of Sacramento Onsite Design Manual, and the Sacramento Region Stormwater Quality Design Manual.

Revised.

Per the plans the detention basin will be discharged to the City drain main in North Avenue.

The report is divided into four (4) main parts:

1. Description of existing drainage conditions and evaluation of pre-construction runoff.
2. Description of proposed drainage improvements, evaluation of post-construction runoff, analysis of proposed storm drainage system, and discussion of water quality treatment applicability.
3. Conclusions based on drainage analysis.
4. Recommendations.

E. EXISTING STORM DRAINAGE CONDITIONS

CWE-RFE used topographic data from a survey performed by Michael Dequine and Associates, Inc. in April, 2018. Using this data, CWE-RFE determined drainage shed limits of the existing site. The site is mostly pervious with some concrete paving and buildings on-site. The frontage includes rolled curb, gutter, and sidewalk with asphalt paving beyond the lip of gutter. The existing drainage sheds can be seen on the Pre-Construction Shed Map, SM1, in Appendix B. There are two primary drainage sheds for the site which terminate in opposite directions. The largest shed includes the entire area from the back of existing sidewalk to the north property line. This area slopes at an average of 2.5% from south to north where it sheet flows to an existing City-owned concrete drainage channel off-site. It is expected that most rainfall is infiltrated for smaller, more common storms as most of the site is undeveloped. The smaller shed includes the project frontage, which conveys flow via curb and gutter to the west where it is accepted by a public drainage inlet beyond the project property. The existing site is approximately 89.3% pervious and is mostly covered by short, dead grass and several trees. There is no existing drainage infrastructure on-site, as the only nearby facilities are a 48" public stormdrain pipe in North Avenue and a City-owned concrete channel north of the property. Existing hydraulic calculations were not done for existing conditions, as the City of Sacramento DOU Onsite Design Manual static method only requires post-development conditions to determine required detention and stormdrain pipe sizing. These methods and results are further discussed later in this report. The existing drainage shed summary can be seen in Table 1 below.

Table 1: Existing Shed Summary

Drainage Shed	Area (SF)	Percent Impervious
A-X1	57,078	3.93%
A-X2 (Frontage)	4,327	100%

*See Pre-Construction Shed Map, SM1, in Appendix A for more information

F. POST-CONSTRUCTION STORM DRAINAGE CONDITIONS

The post-construction storm drainage system was designed to satisfy requirements of the City of Sacramento DOU Design and Procedures Manual and Onsite Design Manual. According to these standards, developments must aim to mitigate post-construction flows using onsite storage methods as well as design storm drain conveyance systems to satisfy certain conditions for the 10-yr and 100-yr storms. For this project, the detention basin was designed using the Static Analysis method as outlined in section 3.1.1 of the Onsite Design Manual and the pipes were analyzed for the 10-yr storm using the rational method (Static Analysis) as outlined in section 3.1.2. The Post-Construction Shed Map, SM2, can be seen in Appendix B.

Onsite Project Storage

According to the DOU Onsite Design Manual, any project that adds more than 500 square feet of impervious surface must be fully mitigated as to not inundate the City's separated stormwater system. For this project, mitigation will be achieved by a singular detention basin for the entire site designed per the Static Method as outlined in section 3.1.1 of the Onsite Design Manual. According to Figure 1 of the manual, this project is in the City of Sacramento drainage basin 157, meaning it must store 7,000 cubic feet of volume for each additional acre of impervious surface resulting from the development. This number is taken from Figure 10 of the Onsite Manual. Comparing the Pre-Construction Shed Map to the Post-Construction Shed Map, there is an increase of 20,442 square feet of impervious surface resulting from this project. That attributes to 0.469 acres of additional impervious surface and therefore 3,285 cubic feet of required detention volume. A summary of the pre and post project land cover can be seen on the shed maps in Appendix B. A summary of the required detention volume calculation can be seen in Table 2 below.

Table 2: Required Detention Volume

Project Condition	Impervious Surface (SF)	Impervious Surface Increase (SF)	Impervious Surface Increase (AC)	Detention Volume Requirement	Detention Design Volume (CF)
Existing	6,571	20,442	0.469	7,000 CF/AC	<u>3,285</u>
Developed	27,013				

For this project, the universal detention basin has been designed to exceed the required capacity based on the Onsite Design Manual and calculated in Table 2. In addition to determining the required volume of the basin, the outlet control structure has been designed based on Equation 3-1 in the Manual. This equation and methodology can be seen in Appendix C and calculations can be seen in Appendix D. Using equation 3-1, an orifice diameter of 2 inches will be used for the outlet control structure.

It should be noted that DMA-5 as seen on the Post-Construction Shed Map is the only shed that does not flow to the on-site detention basin. This shed includes the expanded project frontage and sheet flows to North Avenue. As can be seen on the Pre-Construction Shed Map, shed A-X2 is a similar shed that includes the existing project frontage. It would not be feasible or practical to route DMA-5 to a detention basin as it mimics the existing sheet flow conditions of the project frontage. Additionally, the detention basin was sized to accommodate increased impervious area for the entire site, including DMA-5, and therefore provides attenuation in-lieu of this area. Therefore, this small area will not be designed to flow to the on-site detention basin.

Onsite Hydraulic Analysis and Overland Release

Per the DOU Design and Procedures Manual, project that are less than 10 acres may use the Rational Method to determine flows for designing underground stormdrain pipes. Per the Onsite Design Manual, only a 10-yr event storm analysis is required. The 10-yr flows for this project were calculated per Equations 3-2 and 3-3 of the Manual which implement the rational method using weighted coefficients based on pervious and impervious area and weighted time of concentrations seen in Table 3-1. The methodology can be seen in Appendix C and the calculations can be seen in Appendix D. Using these equations, the flows for each DMA (except DMA-5) can be seen in Table 3 below.

Table 3: 10-YR Design Flows

Drainage Management Area (DMA)	10-YR Design Flow (CFS)
DMA-1	0.557
DMA-2	0.910
DMA-3	0.151
DMA-4	0.309

According to the Onsite Design Manual, private drainage pipe shall be sized to keep the 10-yr storm HGL below vehicular and/or pedestrian access surfaces. To ensure the system meets this requirement, the on-site stormdrain network was analyzed using the AutoCAD Civil 3D extension Hydraflow Storm Sewers. This program uses Manning's equation to do a backwater HGL analysis throughout the stormdrain system, which is consistent with the Onsite Design Manual. The Manual also indicates the starting HGL to be at the invert elevation of all pipes entering the detention basin at the connection point to the facility. The outlet of the detention basin was not analyzed as the basin was designed to fully store the 100-yr storm. Per the calculations as seen in Appendix D, each on-site pipe meets the requirement to keep the HGL below proposed grade. A summary of the results can be seen in Table 4 below.

Table 4: 10-YR HGL Analysis

Pipe #*	10-YR Starting HGL (ft)	10-YR HGL at Drainage Node (ft)	Nearest Vehicular/Pedestrian Elevation at Drainage Node (ft)	Freeboard (ft)
1	25.46'	26.22'	32.74'	6.52'
2	N/A	26.82'	32.86'	6.04'
3	N/A	26.56'	31.10'	4.54'
4	25.46'	31.03'	32.83'	1.8'

The last requirement for this project is that the 100-year event HGL can be obtained from a City drainage masterplan for the appropriate basin, or if none exists the HGL can be assumed to be one-foot above the most downstream adjacent City drainage inlet. If there is no adjacent City drainage system, assume the 100-year event HGL is one-foot above the lowest adjacent street or alley surface elevation fronting the project site.

There is an existing City drainage masterplan 157.

See updated narrative.

The City of Sacramento defers to the Stormwater Quality Design Manual (SQDM) for requirements of hydromodification, low impact development, and stormwater quality. According to Table 3-2 of the manual, single family residential projects with a gross area of less than 20 acres are exempt from these three categories and are only required to implement the source control measures outlined in Table 3-3 of the manual seen below. Table 3-2 can be seen in Appendix C. The development at 905 North Avenue is below this 20 acre threshold and therefore will only be designed for the items below

G. STORMWATER QUALITY EVALUATION

The City of Sacramento defers to the Stormwater Quality Design Manual (SQDM) for requirements of hydromodification, low impact development, and stormwater quality. According to Table 3-2 of the manual, single family residential projects with a gross area of less than 20 acres are exempt from these three categories and are only required to implement the source control measures outlined in Table 3-3 of the manual seen below. Table 3-2 can be seen in Appendix C. The development at 905 North Avenue is below this 20 acre threshold and therefore will only be designed for the items below

Table 5: Post-Construction Source Control Measures

Source Control	Used	Description
Efficient Irrigation	YES	Irrigation to be designed by landscaped architect.
Fueling Areas	N/A	No fueling areas proposed.

DRAINAGE STUDY AND STORM WATER QUALITY CONTROL PLAN

Landscaping	YES	Landscape throughout property, landscaping between building and detention basin, landscape strip between sidewalk and curb
Loading Areas	N/A	No loading areas proposed
Outdoor Storage Areas	N/A	No outdoor storage areas proposed.
Outdoor Work Areas	N/A	No outdoor work areas proposed
Storm Drain Markings and Signs	YES	Storm drains will be marked.
Vehicle/Equipment Wash Areas	N/A	No vehicle equipment wash areas proposed.
Waste Management Areas	N/A	No waste management areas proposed.

Reference Table 3-3 from the Sacramento Region Stormwater Quality Design Manual

H. CONCLUSIONS

- A universal detention basin for the property is designed for a volume consistent with the requirements outlined in the City of Sacramento DOU Onsite Design Manual. This basin will also have an outlet control structure designed per the Manual.
- The 10-yr design storm will be adequately conveyed by the private on-site piping and will contain the HGL elevations under vehicular/pedestrian access areas.
- The development has been designed to maintain a minimum of 6 inches of freeboard from 1 foot above the most downstream adjacent City inlet and 12 inches above the overland release point from the site.
- New impervious areas will require new stormwater quality measures including source control measures only.

I. RECOMMENDATIONS

In order to sufficiently account for on-site and off-site drainage and water quality treatment, as applicable to this project, CWE-RFE recommends that the final design and construction include grading and storm drainage improvements consistent with the 905 North Avenue Improvement Plans and the conclusions outlined in this drainage study.

J. REFERENCES

- Autodesk Hydraflow Extension for AutoCAD Civil 3D 2021
- City of Sacramento Department of Utilities Onsite Design Manual (May 1st, 2020)
- City of Sacramento Department of Utilities Design and Procedures Manual, Section 11 (2018)
- Sacramento Region Stormwater Quality Design Manual (July 2018)




905 NORTH AVENUE

DRAINAGE STUDY AND STORM WATER QUALITY CONTROL PLAN

APPENDIX A

VICINITY MAP AND SITE PLAN EXHIBITS




905 NORTH AVENUE
SACRAMENTO
CALIFORNIA

VICINITY MAP



2260 Douglas Blvd, Suite 160, Roseville, CA 95661
Ph: 916-772-7800 www.cwecorp.com

Z:\2021 Projects\21-188 905 North Ave Sec WORKING CAD\ON-SITE C5-HORIZONTAL CMTL.dwg Jun 02, 2022-10:13 am



NOTES:
DIMENSIONS ARE TO BOTTOM FACE OF CURB UNLESS SPECIFIED OTHERWISE. BUILDING OUTLINE REPRESENT THE OUTER-MOST ELEMENT OF BUILDINGS. CONTRACTOR SHALL REFER TO FOUNDATION PLANS FOR CONSTRUCTION OF FOUNDATION AND BUILDING SLAB.

UNDERGROUND UTILITY NOTE:
THE UNDERGROUND UTILITIES SHOWN HAVE BEEN LOCATED FROM FIELD SURVEY INFORMATION AND EXISTING DRAWINGS. THE SURVEYOR MAKES NO GUARANTEE THAT THE UNDERGROUND UTILITIES SHOWN COMPRISE ALL SUCH UTILITIES IN THE AREA, EITHER IN SERVICE OR ABANDONED. THE SURVEYOR FURTHER DOES NOT GUARANTEE THAT THE UNDERGROUND UTILITIES SHOWN ARE IN THE EXACT LOCATION INDICATED ALTHOUGH HE DOES CERTIFY THAT THEY ARE LOCATED AS ACCURATELY AS POSSIBLE FROM INFORMATION AVAILABLE. THE SURVEYOR HAS NOT PHYSICALLY LOCATED THE UNDERGROUND UTILITIES.

NOTICE TO CONTRACTOR - ORDER OF WORK:
PRIOR TO THE START OF ANY CIVIL WORK, IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY THE HORIZONTAL AND VERTICAL LOCATIONS OF ALL EXISTING UTILITIES BY POT-Holing AT ALL POINTS OF POTENTIAL CONFLICT WITH PROPOSED UTILITIES OR PROPOSED POINTS OF CONNECTION WITH EXISTING UTILITIES. IF THE ACTUAL LOCATIONS OF THE EXISTING UTILITIES FOUND IN THE FIELD ARE DIFFERENT FROM WHAT IS SHOWN ON THESE PLANS, THE CONTRACTOR SHALL CONTACT RFE ENGINEERING IMMEDIATELY AND PROVIDE THE ACTUAL LOCATION INFORMATION. RFE ENGINEERING WILL VERIFY IF THERE ARE ANY CONFLICTS WITH THE IMPROVEMENTS AND WILL PROVIDE MODIFICATIONS TO THE DESIGN TO MITIGATE THE CONFLICTS IF ANY CONFLICTS EXIST.

LEGEND:

BUILDING SETBACK: -----BSL-----BSL-----BSL-----

FIRE LANE STRIPING: _____

FIRE STRIPING KEY NOTE:

① FIRE LANE DESIGNATION STRIPE AS DELINEATED ON THE DRAWINGS. CURBS SHALL BE PAINTED RED MARKED BY WHITE LETTERING "FIRE LANE - NO PARKING" A MINIMUM OF THREE INCHES TALL WITH A 1/2 INCH WIDE MINIMUM STROKE. THE INTERVAL BETWEEN STENCILED LETTERING SHALL BE ADEQUATE TO INFORM THE PUBLIC OF THE EXISTENCE OF THE FIRE LANE BUT IN NO EVENT SHALL THE INTERVAL EXCEED 50 FEET.

APPROVED	BY	DATE	REVISION	CHECK NO.	BY	CHECK	DESIGN	DRAWN	QUANT.	ORIGINAL SCALE IS IN INCHES
										2
										1
										0
REGISTERED PROFESSIONAL ENGINEER No. C 92447 PRELIMINARY NOT FOR CONSTRUCTION OF CAL. WE RFE 2260 Douglas Blvd, Suite 160, Roseville, CA 95661 Ph: 916-772-7800 www.cwecorp.com										
PROPERTY OWNER / DEVELOPER NERRADSCALI CORPORATION 3960 KINGSBARNS DRIVE ROSEVILLE, CA 95747 CONTACT: DAFREN BROWN PH: (916) 300-7962 EMAIL: DARREN@BROWN@COMCAST.NET										
ON-SITE IMPROVEMENT PLANS FOR 905 NORTH AVENUE SACRAMENTO, CA 95838 APN: 237-0200-092 HORIZONTAL CONTROL PLAN										
Sheet C5										
6 of 13 06/02/2022										
CWE-RFE PROJECT NO. 21-188 - 1905 NORTH AVENUE, SACRAMENTO, CA 95838										



Know what's below.
Call before you dig.
or (800) 227-2600




905 NORTH AVENUE

DRAINAGE STUDY AND STORM WATER QUALITY CONTROL PLAN

APPENDIX B

PROJECT SITE SHED MAP EXHIBITS

Z:\2021 Projects\21-188 905 North Ave Site Working CAD\Exhibits\SM-Pre Construction Shed Map-21-188.dwg Jun 02, 2022 10:14 am



LEGEND


DRAINAGE AREA DESIGNATIONS AND AREA

A-X1
3,181 SF

DRAINAGE AREA BOUNDARY

OVERLAND RELEASE

PRE-CONSTRUCTION SHED AREAS (SF)				
DMA	IMPERVIOUS	PERVIOUS	TOTAL	% IMPERVIOUS
	SF	SF	SF	
A-X1	2,244	54,834	57,078	3.93%
A-X2	4,327	0	4,327	100.00%
TOTAL	6,571	54,834	61,405	10.70%



REVISION

DATE

BY

APPRVD

CHECK NO.

BY

DESIGN

DRAWN

QUANT.

0

1

2

ORIGINAL SCALE IS IN INCHES

REGISTERED PROFESSIONAL ENGINEER

NO. C 92447

PRELIMINARY

NOT FOR CONSTRUCTION

STATE OF CALIFORNIA

CWE RFE

2280 Douglas Blvd, Suite 100, Roseville, CA 95661

PH: 916-772-7800 www.cwecorp.com

PROPERTY OWNER / DEVELOPER

NERRADSCALI CORPORATION

3960 KINGSBARNS DRIVE

ROSEVILLE, CA 95747

CONTACT: DARREN BROWN

PH: (916) 300-7962

EMAIL: DARRENBROWN@COMCAST.NET

ON-SITE IMPROVEMENT PLANS FOR

905 NORTH AVENUE

SACRAMENTO, CA 95838

APN: 237-0200-092


PRE-CONSTRUCTION SHED MAP

Sheet

1 of 2

06/02/2022

Z:\2021 Projects\21-188 905 North Ave Sca\WORKING CAD\Exhibits\21-188-POST CON SHED MAP-21-188.dwg Jun 02, 2022-10:36 am





905 NORTH AVENUE

DRAINAGE STUDY AND STORM WATER QUALITY CONTROL PLAN

APPENDIX C

MISCELLANEOUS DOCUMENTATION

is required, it may also include the onsite project drainage design, eliminating the requirement for a separate onsite drainage study.

For onsite drainage studies, the designer may use either a static or dynamic analysis for mitigation sizing and drainage system design as described in the Sections 3.1.1, 3.1.2 and 3.1.3. The same method (either static or dynamic) must be used for the project's entire drainage analysis. Any required drainage design study shall be completed and approved prior to the approval of onsite plans and shall demonstrate conformance with mitigation (Section 3.2.1), finished floor (Section 3.5) and drain pipe criteria (Section 3.6).

An onsite drainage study shall include the following (at a minimum):

- A written description of the project.
- Reference to the City drainage basin that contains the project and regional study if applicable.
- Elevation datum used in study and for all referenced information.
- 10 and 100-year event tailwater elevations and sources.
- Summary of proposed drainage improvements.
- Attached excerpts of studies and other information that may be referenced.
- Summary of the methods used for the drainage study.
- Copies of calculations, spread sheets or computer models.
- An exhibit that:
 - Depicts existing and proposed impervious areas.
 - Shows proposed detention methods and locations including the volume of storage provided.
 - Depicts the onsite drainage system and connection points to the City system; including drainage inlet and manhole locations; and pipe lengths, sizes, slopes and invert elevations.
 - Denotes the elevation and location of the controlling overland release point(s) on the City drainage system. See Section 11.1.3 of the DPM for a definition of overland release point.
 - Depicts onsite drainage shed areas, includes overland release arrows to the public right-of-way and calls out drainage shed breakpoint elevations.
 - Denotes finished floor elevations for all proposed buildings.

3.1.1 Onsite Project Storage Method (Static Analysis)


Projects required to provide drainage mitigation (see Section 3.2.1), not performing a dynamic analysis, shall use the following procedure to size the detention volume and outlet orifice:

1. If required by the DOU, the designer must calculate and replace the volume of storage removed by the project at and below the existing 100-year event hydraulic grade line (HGL) of the City's drainage system, in addition to mitigating for increased imperviousness.
2. To mitigate for increased imperviousness, determine which City drainage basin the project resides in (**Figure 1**) and the associated storage required per acre of increased imperviousness for the 100-year event (as specified in **Figure 10**).
3. Determine the additional acreage of impervious surface resulting from the project. All surfaces shall be considered completely pervious or impervious. Impervious surfaces generally include

- roof-tops and traditional pavement. Green roofs, pervious pavement, gravel, pavers with pervious base and joints shall be considered entirely pervious.
4. Multiply the additional impervious area by the 100-year event storage required per acre. If required, add to the flood replacement volume determined in step 1. The storage volume shall be completely contained at least one-foot above the Invert elevation of the receiving City main.
 5. If a portion of the 100-year event detention volume is being stored within vehicular and/or pedestrian access surfaces, calculate the 10-year event storage volume and ensure it is completely contained within underground pipes and/or designated detention facilities. To determine the 10-year event storage volume, multiply the additional impervious area by the 10-year event storage required per acre for the basin (as specified in **Figure 10**).
 6. Determine the orifice diameter (d) in inches for metering the stored discharge to the City drainage system (see Equation 3-1 and Figure 3-1):
 7. Calculate the maximum head (h) in feet upstream of the orifice, by subtracting the elevation at the center of the orifice from the overland release flow line elevation for the project site (see Figure 3-1),
 8. Determine orifice flow (Q) in CFS, by multiplying the Nominal Capacity of the City drainage basin (as specified in **Figure 10**) by the entire area draining to the detention pond,
 9. Determine the orifice diameter in inches using Equation 3-1.

Equation 3-1
$$d = 6.17 \sqrt{\frac{Q}{\sqrt{h}}}$$

Figure 3-1 Onsite Project Storage Discharge



3.1.2 Rational Method (Static Analysis)

Projects required to provide calculations sizing the onsite drainage system pipes (see Section 3.6), not performing a dynamic analysis, shall use the rational method as specified below; only a 10-year event storm analysis is required.

The 10-year event starting HGL elevation shall be obtained as follows:

- For gravity flow situations without onsite detention, the starting HGL shall be obtained from a previously approved City storm drain master plan that includes the project site. If an approved master plan does not exist, assume the HGL is 0.5-feet above the most downstream adjacent City drainage inlet grate elevation. If there is no gutter, assume the HGL is the lowest adjacent street or alley surface elevation fronting the project site.
- For projects that include onsite dry detention areas, assume the starting HGL for each pipe segment connected to a detention facility is the invert elevation at the segments point of connection to the facility. For onsite detention areas that include a permanent pool, the starting HGL for each pipe segment connected to the pool, is the permanent pool water surface elevation.

Drainage studies utilizing the rational method shall demonstrate all proposed private “drainage pipe” meets the criteria specified in Section 3.6 of this manual, and shall include:

1. Applicable runoff for drainage shed areas using Equations 3-2 & 3-3, and
2. 10-year event HGL throughout the analyzed system utilizing Manning’s equation

Equation 3-2 $Q = CiA_s$

Equation 3-3 $i = at^b$

Where:

Q = Peak flow rate to a particular node (CFS)

C = Runoff coefficient (unit-less, Refer to Table 3-1)

i = Rainfall intensity (inches/hour)

A_s = Shed area draining to a particular Node (acres)

a = Rainfall intensity coefficient = 8.10 (10-year event) and 14.465 (100 -year event)

b = Rainfall intensity coefficient = -0.573 (10-year event) and -0.602 (100-year event)

t = Time of concentration (minutes) = Inlet Time + Time thru pipe/channel to a particular Node (Refer to Table 3-1 for Inlet Time)

Designer shall use an area weighted average of pervious and impervious areas for calculating the C factor and Inlet Time.

Table 3-1 Runoff Coefficients and Inlet Times

Imperviousness/ Land Use	Runoff Coefficient C	Inlet Time t _i
Proposed/Existing Development		
Impervious areas	0.95	5
Pervious areas	0.40	10

3.1.3 Onsite Computer Model (Dynamic Analysis)


Projects may use a computer dynamic model for sizing onsite detention and/or drainage pipe. The model results shall demonstrate that finished floor elevations meet the requirements specified in Section 3.5 and that any proposed drainage pipe meets the criteria specified in Section 3.6.

CITY OF SACRAMENTO DRAINAGE BASINS

Project Site

Legend

-  Drainage Sumps
-  Reservoirs
-  Treatment Plants
-  City Boundary
-  Drainage Basins



0 1,950 3,900 Feet
0 0.25 0.5 1 Miles

City of
SACRAMENTO
Department of Utilities

Basin	Nominal Capacity CFS/AC	Storage per Acre of Increased Imperviousness (Cubic Feet)	
		100-Year	10-Year
138	0.14	8,900	4,450
139	0.17	7,900	3,950
140	0.21	6,700	3,450
141	0.3	5,300	2,700
142	0.25	6,000	3,050
144	0.31	5,200	2,600
147	0.1	10,600	5,500
148	0.37	4,600	2,250
149	UP	NA	NA
151	0.26	5,800	2,950
152	0.23	6,300	3,250
153	0.14	8,900	4,450
154	0.13	9,300	4,700
155	0.26	5,800	2,950
157	0.2	7,000	3,600
158	0.1	10,600	5,500
159	0.05	12,800	7,500
160	0.46	3,800	1,990
161	UP	NA	NA
G200	0.2	7,000	3,600
G201	0.2	7,000	3,600
G204	0.1	10,600	5,500
G205	0.1	10,600	5,500
G206	NN	10,600	5,500
G207	NN	10,600	5,500
G208	NN	10,600	5,500
G209	0.1	10,600	5,500

Basin	Nominal Capacity CFS/AC	Storage per Acre of Increased Imperviousness (Cubic Feet)	
		100-Year	10-Year
G248	0	15,000	10,500
G249	0	15,000	10,500
G250	0.1	10,600	5,500
G251	0.2	7,000	3,600
G252	0.08	11,600	6,200
G253	0.13	9,300	4,700
G254	0.12	9,700	4,950
G255	0.2	7,000	3,600
G256	0.12	9,700	4,950
G257	0.12	9,700	4,950
G258	0.2	7,000	3,600
G259	0.2	7,000	3,600
G260	0.2	7,000	3,600
G261	0.2	7,000	3,600
G262	0.15	8,600	4,300
G263	0.2	7,000	3,600
G264	0.2	7,000	3,600
G265	0.2	7,000	3,600
G266	0.11	10,200	5,200
G267	0.1	10,600	5,500
G268	0.17	7,900	3,950
G269	0.48	3,700	1,950
G270	0.17	7,900	3,950
G271	0.2	7,000	3,600
G272	0	15,000	10,500
G273	0.5	3,700	1,900
CSS	0.18	7,600	3,800

NN = North Natomas 0.1cfs/ac - Mitigate increase in impervious area relative to approved basin wide master plan at 0.1cfs/ac

NN4 = North Natomas 0.4cfs/ac - Mitigate increase in impervious area relative to approved basin wide master plan at 0.4cfs/ac

UP = Underpass - Do not drain to these basins

Note:

100-year event volume must be contained onsite and may include parking lot storage or other surface flooding.

10-year event volume must be completely contained in underground pipe and/or within a detention facility.

11.3.5.2 Exemptions

A Drainage Design Report will not be required when:

1. An approved Drainage Study already exists that includes the Project, which is consistent with this Section as determined by DOU,
2. Project is consistent with site runoff and storage anticipated by existing Drainage Study,
3. All applicable public drainage improvements to be constructed by the Project are defined in existing Drainage Study and consistent with Project, and
4. All applicable improvements identified by existing Drainage Study to serve or mitigate for potential impacts from Project are in-place or will be constructed by Project.

Or,

5. Project does not require public drainage improvements.

11.3.5.3 Conformance with Plans

Infrastructure in Drainage Design Report shall be based on existing improvements and those to be constructed by Project. During the course of Project design, if the Designer modifies the street alignment, lot configuration, impervious area, land use, length, size and alignment of the storm drain pipes, location of a Detention Pond or pump station, On-site storage volume, Stormwater quality measures, etc., the Drainage Design Report shall be revised to reflect these changes. In all cases, the accepted Plans shall match the current accepted Drainage Design Report.

11.3.5.4 Modification of Past Study

If the Project is included in, but does not conform to an existing Drainage Study, the existing Drainage Study must be updated to account for all changes, such as land use, imperviousness, slope, routing, etc.

1. If the Drainage Study utilizes the Rational Method, and the Designer elects to use the Rational Method, proceed to Section 11.3.5.5,
2. If the Drainage study utilizes a dynamic model, proceed to Section 11.3.5.6.

11.3.5.5 Level One - Rational Method

For Projects of less than 10 acres, Designer may elect to analyze Stormwater runoff and routing using the Rational Method. The Rational Method may not be used for Projects with public Detention Ponds or pump stations, or Projects consisting of more than 10 acres including all phases.

Downstream 10 and 100 Year Event HGLs shall be based on an existing Study, if available. If no Study exists for downstream connection, 10 and 100 Year Event HGLs shall be assumed as 0.5-feet and 1.0-feet, respectively above adjacent drain inlet at the most downstream point analyzed.

Level One Drainage Design Report calculations shall include the following:

1. Applicable runoff for sub sheds using Equations 11-1 & 11-2, and
2. 10 & 100 Year Event HGL throughout analyzed system utilizing Manning's equation

Equation 11-1 $Q = CiA_s$

Equation 11-2 $i = at^b$

Where:

Q = Peak flow rate to a particular node (CFS)

C = Runoff coefficient (*unit-less*, Refer to Table 11-1)

i = Rainfall intensity (inches/hour)

A_s = Shed area draining to a particular Node (acres)

a = Rainfall intensity coefficient = 8.10 (10 Year Event) and 14.465 (100 Year Event)

b = Rainfall intensity coefficient = -0.573 (10 Year Event) and -0.602 (100 Year Event)

t = Time of concentration (minutes) = Inlet Time + Time thru pipe/channel to a particular Node (Refer to Table 11-1 for Inlet Time)

Designer shall use a weighted average of pervious and impervious areas for calculating the C factor and Inlet Time.

The discharge Q for sites utilizing metered storage (refer to Onsite Design Manual) may be reduced to the peak discharge rate from the applicable Detention Ponds.

Table 11-1 Runoff Coefficients and Inlet Times

Imperviousness/ Land Use	Runoff Coefficient C	Inlet Time t_i
Proposed/Existing Development		
Impervious areas	0.95	5
Pervious areas	0.40	10

(use area weighted average)

11.3.5.6 Level Two – Dynamic Modeling

Designer shall analyze the Project Stormwater impact and any required mitigation using dynamic modeling for all Projects larger than 10 acres, and may elect to for smaller Projects. Model setup and report parameters shall be in accordance with applicable DOU model user guide. The latest version of the user guides may be obtained from DOU.

Drainage Design Reports in Basins that have a previously approved Storm Drain Master Plan shall utilize the model and software of the approved study. New drainage models shall use XPSWMM for the Separated Drainage System and InfoWorks for the Combined Sewer System.

11.3 DRAINAGE STUDIES

The maximum allowable 10 and 100 Year Event water surface and Overland Release elevations are different for a Greenfield Development versus an Infill Development. All Projects must also meet Existing Development and public safety criteria. Refer to Plate 11-2 MASTER PLANNING CRITERIA EXHIBIT.

Drainage Studies include Storm Drain Master Plans and Drainage Design Reports (Levels 1 or 2). Some Projects may require acceptance of a Storm Drain Master Plan in conjunction with a Tentative Map or other entitlement. DOU will also require acceptance of a Drainage Design Report in conjunction with the Plans for most Projects proposing public drainage improvements.

All Drainage Studies shall be submitted with a Drainage Study Checklist, stamped by a registered civil engineer. If items on the Checklist are deficient, the Drainage Study may be returned for correction without review.

Existing 100 Year Event Stormwater detention volume to be removed by Project shall be accounted for in Drainage Study and replaced as necessary, in addition to other mitigation measures required herein. Typical minor losses shall be disregarded (Refer to Section 11.4.5).

Elevations for Separated Drainage studies shall be tied to a City benchmark, Datum NAVD 88. Elevations for Combined Sewer studies shall be tied to a City benchmark, Datum NGVD 29.

If a Project is required to comply with Stormwater quality standards, detailed analysis and sizing calculations shall be included with the Drainage Study (Refer to Section 11.11). Drainage Studies need not include on-site privately maintained drainage pipes and appurtenances, except as applicable to mitigate Project impacts to the public drainage system. Requirements for the design of such On-Site drainage facilities and sizing of drainage services are covered by the Onsite Design Manual.

11.3.1 Greenfield Development

The 10 Year Event HGL shall be a minimum of 6-inches below all new DI Grates. The Finished Floor of new structures shall be at least 12-inches above the 100 Year Event HGL, and 18-inches above the Overland Release Point (Refer to Section 11.7).

11.3.2 Infill Development

The 10 Year Event HGL shall be at or below all new DI Grates placed in gutters. Refer to 11.3.7 for inlets placed in roadside ditches. The Finished Floor of new structures shall be at least 6-inches above the 100 Year Event HGL and 12-inches above the Overland Release Point (Refer to Section 11.7).

Table 3-2 Required Stormwater Quality Control Measures for Priority Projects

Priority Project Categories ⁽¹⁾	Required Stormwater Quality Control Measures				
	Source Control ⁽²⁾	Hydromodification Control ⁽³⁾	Low Impact Development Control	Treatment Control	Full Capture Trash Control ⁽⁷⁾
Single Family Residential Impervious area $\geq$ 1 acre	X		X		X For projects with at least 10 du/acre ⁽⁸⁾
Single Family Residential Gross Area $\geq$ 20 acres	X	X	X	X	
Multi-family Residential Impervious Area $<$ 1 acre	X				
Multi-family Residential Impervious Area $\geq$ 1 acre	X	X	X	X	
Commercial/ Industrial Development ⁽⁶⁾ Impervious area $<$ 1 acre	X				X For industrial projects where primary activities involve product manufacture, storage, or distribution. For commercial projects where primary activities involve sale or transfer of goods or services to consumers
Commercial/ Industrial Development ⁽⁶⁾ Impervious area $\geq$ 1 acre	X	X	X	X	
Automotive Repair Shops ⁽⁶⁾ Impervious area $<$ 1 acre	X				
Automotive Repair Shops ⁽⁶⁾ Impervious area $\geq$ 1 acre	X	X	X	X	
Retail Gasoline Outlet ⁽⁶⁾ Impervious area $<$ 1 acre	X				
Retail Gasoline Outlet ⁽⁶⁾ Impervious area $\geq$ 1 acre	X	X	X	X	
Restaurants Impervious area $<$ 1 acre	X				
Restaurants Impervious area $\geq$ 1 acre	X	X	X	X	
Hillside Development Slope $\geq$ 25%	X	X	X	X	
Parking Lots ⁽⁴⁾⁽⁶⁾ Impervious area $<$ 5,000 square feet or 25 parking spaces	X				X For Public Transportation Stations, which are facilities or sites where public transit agencies' vehicles load or unload passengers or goods (e.g., bus stations and stops)
Parking Lots ⁽⁴⁾⁽⁶⁾ Impervious area $\geq$ 5,000 square feet or 25 parking spaces	X	X	X	X	
Streets & Roads ⁽⁵⁾⁽⁶⁾ Impervious area $<$ 5 acres	X				
Streets & Roads ⁽⁵⁾⁽⁶⁾ Impervious area $\geq$ 5 acres	X	X	X	X	

Table 3-3 Stormwater Quality Control Measure Selection Matrix

✓ Required Based Upon Table 3-2

• Acceptable Option

“NA” Not applicable or allowed

Priority Project Category ^(a)	Residential			Commercial/Industrial							
Control Measure	Single Family Residential Impervious area ≥ 1 ac	Single Family Residential Gross area ≥ 20 ac	Multi-family Residential Impervious area ≥ 1 ac	Commercial Impervious area ≥ 1 ac	Auto Repair Shops Impervious area ≥ 1 ac	Retail Gasoline Outlets Impervious area ≥ 1 ac	Restaurants Impervious area ≥ 1 ac	Industrial Impervious area ≥ 1 ac	Hillside Developments ≥ 25% slope	Parking lots ^(b) ≥ 5,000 sf or 25 spaces	Streets/Roads ^(c) Impervious area ≥ 5 ac
Source Control ^(d)	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Efficient Irrigation	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Fueling Areas	NA	NA	NA	✓	✓	✓	✓	✓	✓	NA	NA
Landscaping	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Loading Areas	NA	NA	NA	✓	✓	✓	✓	✓	✓	NA	NA
Outdoor Storage Areas	NA	NA	NA	✓	✓	✓	✓	✓	✓	NA	NA
Outdoor Work Areas	NA	NA	NA	✓	✓	✓	✓	✓	✓	NA	NA
Storm Drain Markings and Signs	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Vehicle/Equipment Wash Areas	NA	NA	✓	✓	✓	✓	✓	✓	✓	NA	NA
Waste Management Areas	NA	NA	✓	✓	✓	✓	✓	✓	✓	✓	NA
Hydromodification Control, LID, and Treatment Control ^{(e)(f)}	(LID Only)	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Alternative Driveways	•	•	•	NA	NA	NA	NA	NA	•	NA	NA
Capture and Re-Use	•	•	•	•	•	•	•	•	•	NA	NA
Compost-Amended Soil	•	•	•	•	NA	NA	•	•	NA	•	NA
Constructed Wetland Basin	•	•	•	•	NA	NA	•	•	NA	•	•
Disconnected Pavement	•	•	•	•	•	•	•	•	•	•	•
Disconnected Roof Drains	•	•	•	•	•	•	•	•	•	NA	NA
Green Roof	NA	NA	NA	•	•	•	•	•	•	NA	NA
Infiltration Basin	•	•	•	•	NA	NA	•	NA	NA	•	•
Infiltration Trench	•	•	•	•	NA	NA	•	NA	NA	•	•



905 NORTH AVENUE

DRAINAGE STUDY AND STORM WATER QUALITY CONTROL PLAN

APPENDIX D

SUPPORTING CALCULATIONS



Post-Construction Design Flows (10-yr Storm)


Project: 905 North Avenue
Location: 905 North Avenue, Sacramento, CA 95838
Jurisdiction: City of Sacramento
Designer: MJW
Date: 6/2/2022

Drainage Shed	Associated Node	Shed Area		Node Tributary Area		Shed Percent Impervious	Shed Weighted Runoff Coefficient	Shed Weighted Inlet Time	Rainfall Intensity ¹	10-yr Flow ²
		sf	acre	sf	acre	%	C	t (min)	in/hr	CFS
DMA-01	A1	18,188	0.418	53,711	1.233	30%	0.562	8.524	2.373	0.557
DMA-02	A2	26,185	0.601	26,185	0.601	39%	0.617	8.031	2.455	0.910
DMA-03	A3	4,945	0.114	4,945	0.114	29%	0.561	8.533	2.371	0.151
DMA-04	A4	4,393	0.101	4,393	0.101	100%	0.950	5.000	3.221	0.309

¹Rainfall Intensity based on Equation 3-3 of the City of Sacramento DOU Onsite Design Manual

²Flow equation based on Equation 3-2 of the City of Sacramento DOU Onsite Design Manual

Hydraflow Storm Sewers Extension for Autodesk® Civil 3D® Plan



Project File: 905 North Ave.stm	Number of lines: 4	Date: 6/2/2022
---------------------------------	--------------------	----------------

RFE Data

Line No.	Inlet ID	Line ID	DnStm Ln No	Flow Rate	Capac Full	Line Size	Line Length	Invert Up	Invert Dn	Line Slope	Gnd/Rim El Up	Cover Up	Runoff Coeff	i Sys	Drng Area	Total Area	Tc	Pipe Travel	n-val Pipe	Incr Q	
				(cfs)	(cfs)	(in)	(ft)	(ft)	(ft)	(%)	(ft)	(ft)	(C)	(in/hr)	(ac)	(ac)	(min)	(min)		(cfs)	
1	MH1	D4	Outfall	1.22	9.10	18	35.016	25.81	25.46	1.00	32.74	5.43	0.00	0.00	0.00	0.00	8.5	0.85	0.015	0.00	
2	DMA-4	D5	1	0.31	3.09	12	77.760	26.59	25.81	1.00	32.86	5.27	0.00	0.00	0.00	0.00	5.0	3.28	0.015	0.31	
3	DMA-2	D6	1	0.91	3.12	12	34.268	26.16	25.81	1.02	31.10	3.94	0.00	0.00	0.00	0.00	8.0	0.49	0.015	0.91	
4	DMA-3	D3	Outfall	0.15	8.90	12	65.000	30.87	25.46	8.32	32.00	0.13	0.00	0.00	0.00	0.00	8.5	5.67	0.015	0.15	
Project File: 905 North Ave.stm												Number of lines: 4				Date: 6/2/2022					
NOTES: Known Qs only. ; ** Critical depth																					

RFE Data

HGL Up	HGL Dn	Rim-Hw	Vel Up	Vel Dn	Hw	Crit Depth
(ft)	(ft)	(ft)	(ft/s)	(ft/s)	(ft)	(ft)
26.22	25.83	6.52	3.09	3.58	0.41	0.41
26.82 j	26.22	6.04	2.28	1.01	0.23	0.23
26.56 j	26.22	4.54	3.11	2.97	0.40	0.40
31.03	25.55	0.97	1.88	4.25	0.16	0.16
Project File: 905 North Ave.stm						
Number of lines: 4						
Date: 6/2/2022						
NOTES: ** Critical depth						



WATER STUDY FOR 905 NORTH AVENUE

Sacramento, CA 95838

June 3, 2022



**Prepared by,
CWE-RFE
2260 Douglas Blvd., Suite 160
Roseville, CA 95661
Ph 916-772-7800
CWE-RFE Project No. 21-188**



TABLE OF CONTENTS

A.	PROJECT LOCATION.....	4
B.	EXISTING SITE CONDITIONS	4
	Table 1: Site Description (Surrounding Areas).....	4
C.	PROPOSED PROJECT DESCRIPTION.....	5
D.	PURPOSE OF REPORT	5
E.	EXISTING WATER CONDITIONS	6
	Table 1: Water Supply Test Results (Baseline)	6
	Table 2: Water Supply Test Results (Flowed).....	6
	Table 3: Design Water Supply Data	6
F.	POST-CONSTRUCTION WATER CONDITIONS.....	7
	Table 4: Case 1 Results	7
	Table 5: Case 2 Results	8
G.	CONCLUSIONS	8
H.	RECOMMENDATIONS	8
I.	REFERENCES	9



APPENDIX

APPENDIX A	VICINITY MAP AND SITE PLAN EXHIBITS
APPENDIX B	PROJECT WATER MAP
APPENDIX C	MISCELLANEOUS DOCUMENTATION
APPENDIX D	WATER CALCULATIONS AND EPANET REPORT

A. PROJECT LOCATION

The proposed residential grading, drainage, and utilities project is located east of the intersection of North Avenue and Rio Linda Boulevard, just south of Interstate 80 in the City of Sacramento, State of California, 95838. The approximate coordinates of the project site are latitude 38.640581° north and longitude -121.445747° west. The project property is about 1.41 acres and has APN 237-0200-092. Approximately 1.32 acres will be disturbed as part of this project, which includes off-site improvements encompassing the widening of North Avenue. The project's location is shown on the Vicinity Map in Appendix A.

B. EXISTING SITE CONDITIONS

In its existing condition, the site is partially developed with a house on-site with driveway access to North Avenue. Additionally, there are two wooden sheds and one metal shed north of the existing house. There is an electrical transmission tower located at the northeast corner of the property which includes a 100-foot-wide easement that encumbers a portion of the eastern part of the site. The southern property line extends 20 feet beyond the existing right-of-way, and there is rolled curb, gutter, and sidewalk along the project frontage, between the City right-of-way and the southern property line. The remainder of the site is undeveloped and contains a fair number of trees and short, dead grass. The existing house has a residential water connection to the City main in North Avenue.

The City water main varies from 8" to 6" in North Avenue and runs west to east, south of the road centerline. There is an existing fire hydrant at the southwest corner of North Avenue and Palmetto Street where a water supply test was performed by the City, and where the system flows and pressures are to be assumed. The water main is 8" in diameter for the majority of the frontage, and reduces to a 6" line at a tee near the southeast corner of the property. The Project Water Map, in Appendix B shows existing conditions on the project site.

Table 1 below summarizes the surrounding properties.

Table 1: Site Description (Surrounding Areas)

North	City-owned concrete channel, beyond which is Interstate 80
South	North Avenue, beyond which are residential properties
East	North Avenue Apartments
West	Residential property

C. PROPOSED PROJECT DESCRIPTION

This project proposes to improve the site by subdividing the property into 8 lots and constructing residential structures on each lot (except the lot with the existing house). Additionally, a private access drive, easement, and adjacent pedestrian sidewalk will be constructed to provide access and fire protection to the landlocked lots. North avenue will be widened to the standard 35.5' half width right-of-way of a minor collector per City of Sacramento standards. This will include additional paving and rolled curb, gutter, and detached sidewalk within the expanded public right-of-way. The existing house lot and one other lot will have direct access to North Avenue, while the remaining 6 will connect to the private access drive, which will have driveway access to North Avenue at the southeast corner of the property. In addition to the aforementioned improvements, the project proposes landscaping and underground water, sanitary sewer, and drainage infrastructure.

The project's water improvements include a private 6" water main that will connect to the existing 6" water main in North Avenue. This main will be shared by 6 of the 8 proposed residential lots with private water services to each house. Additionally, the undeveloped lot fronting North Avenue will connect its own private service to the 8" portion of the public main in the street. The final lot, which already has a constructed house, currently has a water service connection installed. In addition to the water services, two private fire hydrants are proposed along the shared private access drive, coming off the proposed 6" private line. See section F for an in-depth discussion of the proposed water improvements. Other underground infrastructure will include sanitary sewer lines, as well as minimal storm drain piping to convey flows to the basin.

The total area to be disturbed will be approximately 1.32 acres. The Site plan in Appendix A shows the proposed site and the Project Water Map in Appendix B shows proposed water system.

D. PURPOSE OF REPORT

The purpose of this report is to present the design of the private water system and to demonstrate that the design complies with the City of Sacramento project conditions of approval dated July 9, 2020 regarding water system requirements.

The report is divided into four (4) main parts:

1. Description of the existing water system conditions.
2. Description of proposed water system, evaluation of post-construction water demand, and analysis of proposed water distribution system.
3. Conclusions based on water analysis.
4. Recommendations.

E. EXISTING WATER CONDITIONS

CWE-RFE used topographic survey data from a survey performed by Michael Dequine and Associates, Inc. in April, 2018 as well as a water supply test performed by the City of Sacramento Department of Utilities on March 11, 2022. Using this data, CWE-RFE determined the existing sizes and layouts of the public water system along with existing flow and pressure conditions. The City of Sacramento tested two fire hydrants in the vicinity of the project to determine static and residual pressures and associated flows. The existing conditions can be seen on the Project Water Map in Appendix B. The City flowed hydrants numbers 401 and 501 during their test. For the purposes of this study, the basis for the water analysis will be the design water supply data, provided by the City. The public water map and water supply test results can be seen in Appendix C. A summary of these results can be seen in Table 1 below.

Table 1: Water Supply Test Results (Baseline)

Hydrant Condition	Hydrant Number	Static Pressure (PSI)	Residual Pressure (PSI)
Residual	402	50	32

Table 2: Water Supply Test Results (Flowed)

Hydrant Condition	Hydrant Number	Pitot Pressure (PSI)	Calc. Flow @ Pressure (GPM)	Flow @ 20 PSI (GPM)
Flowed	401	16	1805	1750
Flowed	501	9	503	488

Table 3: Design Water Supply Data

Static Pressure (PSI)	Residual Pressure (PSI)	Total Flow @ Residual (GPM)	Total Flow @ 20 PSI (GPM)
37	19	2300	2200

update per new Water Supply Test

Tables have been updated per new Water Supply test

F. POST-CONSTRUCTION WATER CONDITIONS

The post-construction water distribution system was designed to comply with the City of Sacramento project conditions of approval dated July 9, 2020. According to these conditions, the water system must satisfy the more critical of the following two conditions:

1. At maximum day peak hour demand, the operation or “residual” pressure at all water service connections shall be at least 30 pounds per square inch.
2. At average maximum day demand plus fire flow, the operation or “residual” pressure in the area of the fire shall not be less than 20 pounds per square inch.

In order to show the adequacy of the proposed system to meet these requirements, the existing and proposed water layouts were modeled in EPANET 2.2 and the specific demands were applied to points along the system. This was modeled by adding a “pump” to the system at the location of fire hydrant number 401 with a pump curve equivalent to the flows and pressures supply test in Table 3. From there, the existing and proposed water system was modeled at each system junction. EPANET then automatically calculates friction loss using the Williams method during the analysis, and minor loss coefficients were added for losses due to valves, bends, etc. The water demand assumptions are as outlined in the specific cases noted in the conditions of approval.

For the first case, the assumed maximum day peak hour demand for each residential water service is 50 GPM. For the second case, the assumed average maximum day demand for water service is 10 GPM with a fire flow of 500 GPM (per California Fire Code).

For the first case model, a demand of 50 GPM was placed on each node representing a water service connection and the model was run to determine the pressures at each node. The analysis can be seen in Table 4 below as well as in Appendix D.

attach current CA Fire Code Table and highlight/show how the 500 gpm is obtained. Please note if 500gpm is the reduced fireflow because bldgs are sprinklered, include the sprinkler demands in the assessment.

CA Fire Code Table has been added to Appendix C. Fire Sprinkler Plans by architect also provided.

Table 4: Case 1 Results

Service ID	Demand (GPM)	Residual Pressure (PSI)
SERV1	50	36.90
SERV2	50	36.04
SERV3	50	36.62
SERV4	50	36.93
SERV5	50	36.93
SERV6	50	36.92
SERV7	50	36.91

Based on these results, the water system meets the requirements for maintaining a minimum of 30 PSI for each water service connection at maximum peak hour demand.

For the second model, a demand of 10 GPM was placed on each node representing a water service connection and a fire flow of 500 GPM was placed on the most downstream node to represent a worst-case condition during a fire. The results of this analysis can be seen in Table 5 below as well as in Appendix D.

Table 5: Case 2 Results

Service ID	Demand (GPM)	Residual Pressure (PSI)
SERV1	50	36.64
SERV2	50	33.53
SERV3	50	33.16
SERV4	50	31.02
SERV5	50	30.94
SERV6	50	30.39
SERV7	550	30.33

Based on these results, the water system meets the requirements for maintaining a minimum of 20 PSI in the area of fire.

G. CONCLUSIONS

- The water distribution system will maintain the required pressures of the project conditions of approval for the two cases outlined by the City of Sacramento Department of Utilities.

H. RECOMMENDATIONS

In order to sufficiently account for the performance of the proposed water distribution system, CWE-RFE recommends that the final design and construction include water improvements consistent with the 905 North Avenue Improvement Plans and the conclusions outlined in this water study.



I. REFERENCES

- EPANET 2.2
- City of Sacramento Project Conditions of Approval for 905 North Avenue, dated July 9, 2020.
- California Fire Code 2019




905 NORTH AVENUE

WATER STUDY

APPENDIX A

VICINITY MAP AND SITE PLAN EXHIBITS




905 NORTH AVENUE
SACRAMENTO
CALIFORNIA

VICINITY MAP



2260 Douglas Blvd, Suite 160, Roseville, CA 95661
Ph: 916-772-7800 www.cwecorp.com



Sheet
C5
6 of 13
06/02/2022



Know what's below.
Call before you dig.
 or (800) 227-2600



905 NORTH AVENUE

WATER STUDY

APPENDIX B

PROJECT WATER MAP



APPENDIX C

MISCELLANEOUS DOCUMENTATION

WATER SUPPLY TEST - DEPARTMENT OF UTILITIES

City of Sacramento Community Development Dept. 300 Richards Blvd., 3rd Floor Sacramento, CA 95811	WORK ORDER #: 558907	WST NUMBER: 2201429
	ANALYSIS FEE: \$519.00	DATE PAID: 2.28.22
	FIELD TEST FEE: \$1,092.00	DATE PAID: 2.28.22
	HYDRAULIC BOUNDARY CONDITION	DATE PAID:
CONTACT: Michael Wilson	FEE: \$615.00; optional see item (3) below.	TEST NUMBER: 1 of 1
COMPANY: RFE Engineering Inc	PHONE NUMBER: 916-772-7800	EMAIL: mwilson@rfeengineering.com
ADDRESS: 2260 Douglas Blvd, Ste 160 Roseville Ca 95661	BOUNDARY CONDITION: 905 North Ave	
	ASSESSOR'S PARCEL NUMBER: 237-0200-092	

The undersigned agrees to the following items and conditions:

- (1) The street address and/or parcel number shown above is correct
- (2) Water supply data is developed from several sources of information which may include water supply test data, computer models, and pressure recording stations. The water supply data given is to be used for design purposes.
- (3) Based on hydrant locations, test results may not provide accurate flow information at the point of connection, for a fee the City can provide the hydraulic analysis necessary to transfer the results to a single point of connection.
- (4) Although the water supply data reported herein is believed to be accurate, the City makes no warranty, guaranty, certification or other representation of any kind that such data is accurate or correct, or that the pressures and/or flow rates reported herein can or will be maintained. The undersigned, its officers and employees shall not be liable for any damages of any kind resulting from the water supply data reported herein by the undersigned or by any third party.
- (5) When more than one water supply test has been performed, the undersigned shall check the Plan Checker as to which water supply test is to be used.
- (6) If the undersigned desires to witness the water supply test performed by the City, please check the box below:
☐ I want to witness this water supply test, which will be scheduled at the convenience of the Department of Utilities.
- (7) If the undersigned elects to hire a licensed engineer, at the undersigned's expense, to witness and certify the water supply test performed by the City, please check the box below:
☐ At my expense, I will arrange for a licensed engineer to witness and certify the water supply test, which will be scheduled at the convenience of the Department of Utilities.

Water Supply Test must be within 1 year. Retest per current WST method: Flow FH 402 R19, gauge nearby domestic/fire service.

Water Supply Test was redone. New report added.

PRINT NAME: Michael Wilson
 DATE: 1.20.22

SIGNATURE: _____

DATE OF TEST: 3/11/2022				TIME OF TEST: 5:45 AM						
WTR. MAIN SIZE: 8				TEST CONDUCTED BY: M.Farinias						
	Hydrant Number	Map Page	Static Pres. (PSI)	Residual Pres. (PSI)	Pitot Pres. (PSI)	Outlet Dia. (Inches)	Coefficient		Calc. Flow @ Pres. (GPM)	Flow @ 20 PSI (G.P.M.)
							C ₁	C ₂		
Residual	402	R19	50	32						
Flowed	401	R19			16	4.5	0.90	0.83	1805	1750
Flowed	501	R19			9	2.5	0.90	1.00	503	488
Flowed										
Flowed										

* THE WATER SUPPLY TEST DATA IS NOT TO BE USED FOR THE DESIGN OF DOMESTIC WATER SYSTEMS.
 * (STATIC PRES. - RESIDUAL PRES.) / (STATIC PRES. - 20 PSI) MUST NOT BE LESS THAN 25%. THEREFORE, THESE RESULTS ARE ONLY VALID FOR RESIDUAL PRESSURES LESS THAN 43 PSI

WATER SUPPLY DATA SUMMARY

	Design (1)
Static Pressure	37 PSI
Residual Pressure	19 PSI
Total Flow @ Residual	2300 G.P.M.
Total Flow @ 20 PSI	2200 G.P.M.

- (1) The Design Water Supply Data reflects fluctuations and future demands on the water distribution system. It is to be used for design purposes.

30

7/2019

VALVES								
New ID	Old ID	Old Map	SizeOpen	Type	Turns	SVC Type	Location	SVC Address
101	101	39N		GTVLV			3' EE fence line of pumping station - 2' NN fence of Hwy 80	
102	94	39N		BLVLV			70' SSLL 4103 Rio Linda Blvd - 5'East of pole line	
103	109	39N		BLVLV			1'SS Fence Box Culvert - 1' W C/L Biketrail	
104	110	39N		ARVLV			64' NSPL Freeway - 2' W C/L Biketrail	
201	99	39N		GTVLV			17' North of hydrant 202 - 17' WEC May St	
202				SVVLV			21' SNC - 23' WEC May St	
203				SVVLV			26' SNC - 23' WEC of May St.	
301	111	40N		GTVLV			11' WEC Dry Creek Rd (S) - 12' SNC 4048 Dry Creek Rd	
302	110	40N		GTVLV			12' WEC Dry Creek Rd (S) - 15' SNC 4048 Dry Creek Rd	
303	127	40N		GTVLV			4' SSC O'Donnell Av - 16' WEC Haywood St	
304	136	40N		SVVLV			Dom Svc - 9' WEC Dry Creek Rd (S) - 90' NNC	4029 Dry Creek Road
305	128	40N		GTVLV			1' NSC Jean Av - 12' EWC Haywood St	
306	129	40N		GTVLV			8' SNPL Jean Av - 24' EWPL Haywood St	
401	111	39N		BLVLV			15' SSC North Av - 55' EEC Rio Linda Blvd	
402	95	39N		GTVLV			8' NSC North Av - 15' EWPL Rose St	
403	1	39N		GTVLV			11' NSC North Av - 4' EWPL Cypress St	
404	2	39N		GTVLV			11' NSC North Av - 14' EWPL Cypress St	
405	3	39N		GTVLV			9' NSC North Av - 142' WWC Cypress St	
406	112	39N		ARVLV			121' SSC North Av - 55' EEC Rio Linda Blvd (in MH)	
407	113	39N		BLVLV			12' WEC Rio Linda Blvd - 159' NNC Harris Av	
501	100	39N		GTVLV			10' NSC North Av - 11' EWC May St	
502	5	39N		GTVLV			5' NSC North Av - On WPL	
503	6	39N		GTVLV			10' SSC North Av - 11' WEPL Alley (Branch & May Sts)	
504	7	39N		GTVLV			9' SSC North Av - 4' WEPL Alley (May & Belden Sts)	
505	4	39N		GTVLV			12' SSC North Av - On WPL (Cypress & Branch Sts)	
506	1	40N		GTVLV			3' WEPL alley - 11' SSC North Av	
507				SVVLV			99' WWC of Branch St - 7' NSC of North Ave.	
601	109	40N		GTVLV			2' NSC Jean Ave - 3' WWC Dry Creek Rd	
602	130	40N		GTVLV			On SPL Jean Av - 19' EWPL Haywood St	
603	131	40N		GTVLV			7' NSC North Av - 8' WWC Haywood St	
604	106	40N		GTVLV			20' EWC Dry Creek Rd - 11' NSC North Av (E)	
605	137	40N		GTVLV			135' EEPL Haywood Av - 9' NSPL North Av	
606	107	40N		GTVLV			18' EWC Dry Creek Rd - 2' NSC North Av (E)	
607	108	40N		GTVLV			2' WEC Dry Creek Rd - 5' NSC North Av (E)	
608	2	40N		GTVLV			3'West of pole line - 11' SSC	
609	3	40N		GTVLV			12' SSC North Ave - 5'West of pole line	
610	4	40N		GTVLV			14' East of pole line - 7' NSC North Av	
701	10	39N		GTVLV			33'North of hydrant 202 - 39' EWC	
702	58	39N		GTVLV			2' NNC Harris Av - 3' WEPL Cypress St	
703	57	39N		GTVLV			34' EWC - 23'North of hydrant 702	
704	25	39N		GTVLV			5' WEPL Alley - 5' SSC Harris Av	
705	70	39N		GTVLV			5' WEPL - 5' NSPL Well 129	
706	83	39N		SVVLV			Fire Svc - 338' NNC Grand Av - 9' EWPL Alley (Rose & Palmetto Sts)	
707	81	39N		SVVLV			Metered Svc - 217' NNC Grand Av - 8' EWPL Alley (Rose St & Palmetto St)	
801	60	39N		GTVLV			6' SNC Harris Av - On EPL Alley (May & Branch Sts) On WLL 1017 May St	
802	9	39N		GTVLV			10' WEPL alley (Cypress & Branch Sts) - 6' SNC Harris Av - 1' EELL 3933 Harris Av	
803	59	39N		GTVLV			8' SNC Harris Av - 4' WEPL OF ALLEY	
804	8	39N		GTVLV			1' SSC - 3' EWPL OF ALLEY	
805	14	40N		GTVLV			4' WEPL alley - 11' NSC Harris Av	
901	73	40N		GTVLV			6' SNC Harris Av - 9' EWPL alley	
902	112	40N		GTVLV			20' EWC Dry Creek Rd - 9' SNC Harris Av (E)	
903	46	40N		GTVLV			14' WEPL alley - 8' NNC Harris Av	
904	72	40N		GTVLV			8' SNC Harris Av - 3' EWPL alley	
905	16	40N		GTVLV			5' SSC Harris Av - 7' WEPL alley (Clay & Dry Creek)	
906	15	40N		GTVLV			9' EWPL alley - 4' NSC Harris Av	

HYDRANTS								
New ID	Old ID	Old Map	Make	Type	Pic Code	Valve Distance	main Distance	Location
201	33	39N	M	WH	M6-5 1/4K	Use GV110 & GV128 map	End of main	S side O'Donnell Av - 6' WELL 1036
202	45	39N	M	STD	M6-5 1/4K	19' W - 5' N	20' E	E side May St (between North Av & Hwy 80) End of May St.
203	34	39N	M	STD	M6-5 1/4K	Use GV128 map	End of main	N side Jean Av - End of Ct.
301	36	40N	M	STD	M2-4 1/4G	13' W	17' E	E side Dry Creek Rd - SLL 4101 Dry Creek Rd
302	41	40N	M	STD	M6-5 1/4H	12'N	5' S	SE Cor O'Donnell Av & Haywood St
303	40	40N	D	STD	D1-4 1/2H	9' N	5' S	S side O'Donnell Av - 120' WWPL Dry Creek Rd
304	35	40N	M	STD	M5-4 1/2H	42'E	8' W	NW Cor Jean Av & Dry Creek Rd
401	42	39N	K	STD	K4-4 1/2H	16' N	17' S	SW Cor North Av & Palmetto St
402	4	39N	K	STD	K4-4 1/2H	15' N	17' S	SW Cor North Av & Cypress St
501	3	39N	PS	STD	PS5-4H	11' N	12' S	S side North Av - SW Cor alley (Branch & May Sts)
502	2	39N	K	STD	K11-5 1/4H	14' N	16' S	SW Cor. Belden & North
601	34	40N	M	STD	M6-5 1/4H	4' N	8' S	SE Cor Jean Av & Haywood St
602	6	40N	PS	STD	PS5-4H	8' N	11' S	SW Cor North Av & Clay St
603	52	40N	K	STD	K8-4 1/2H	26' N		SE Cor Haywood St & North Av
604	5	40N	MH	STD	MH2-4 1/4H	14' N	15' S	S side North Av - 1240 North Av - 6' EWLL
605	1	40N	PS	STD	PS5-4H	25' E	27' W	W side Dry Creek Rd - 2' NSLL 3921 Dry Creek Rd
701	21	39N	K	STD	K4-4 1/2H	30' S	31' N	NW Cor Harris Av & Cypress St (RO101700)
702	5	39N	W	STD	W1-5 1/4H	2' E - 2' S	5' W	W side Rio Linda Blvd at Well Site #129
703	38	39N	K	PRIV	K4-4 1/2H	1' E	End of main	E side Rose St - 250' S Harris St
801	22	39N	K	STD	K4-4 1/2H	8' S	10' N	NE Cor Harris Av & alley (Branch & May Sts)
802	23	39N	K	STD	K4-4 1/2H	13' S	14' N	NW Cor Harris Av - alley (Belden & Haywood Sts)
901	23	40N	K	STD	K4-4 1/2H	10' S	12' N	NE Cor Harris Av & alley (Clay St & Dry Creek Rd)
902	53	40N	K	STD	K8-4 1/2H	35' N		SW Cor Clay St & Harris Av



Hydran
Info.




905 NORTH AVENUE

WATER STUDY


APPENDIX D

WATER CALCULATIONS AND EPANET REPORT



update curve per latest
water supply test.

Curve updated



Network Table - Nodes				
Node ID	Demand GPM	Head ft	Pressure psi	Quality
Junc JUN1	0.00	151.78	50.60	0.00
Junc JUN2	0.00	120.33	37.00	0.00
Junc JUN3	0.00	119.96	36.43	0.00
Junc JUN4	0.00	119.73	36.27	0.00
Junc SERV2	50.00	119.21	36.04	0.00
Junc JUN6	0.00	119.01	36.42	0.00
Junc SERV3	50.00	118.89	36.62	0.00
Junc JUN8	0.00	118.58	37.39	0.00
Junc JUN9	0.00	118.34	36.96	0.00
Junc SERV4	50.00	118.29	36.93	0.00
Junc SERV5	50.00	118.28	36.93	0.00
Junc SERV6	50.00	118.24	36.92	0.00
Junc SERV7	50.00	118.23	36.91	0.00
Junc SERV1	50.00	120.19	36.90	0.00
Resvr RES1	-350.00	35.00	0.00	0.00

 Network Table - Links

Link ID	Flow GPM	Velocity fps	Unit Headloss ft/Kft	Friction Factor	Reaction Rate mg/L/d	Quality	Status
Pipe PIPE3	300.00	1.91	1.65	0.019	0.00	0.00	Open
Pipe PIPE4	300.00	3.40	8.54	0.024	0.00	0.00	Open
Pipe PIPE5	300.00	3.40	6.96	0.019	0.00	0.00	Open
Pipe PIPE6	250.00	2.84	4.99	0.020	0.00	0.00	Open
Pipe PIPE7	250.00	2.84	5.50	0.022	0.00	0.00	Open
Pipe PIPE8	200.00	2.27	3.17	0.020	0.00	0.00	Open
Pipe PIPE9	200.00	2.27	3.27	0.020	0.00	0.00	Open
Pipe PIPE10	200.00	2.27	4.34	0.027	0.00	0.00	Open
Pipe PIPE11	150.00	1.70	10.70	0.119	0.00	0.00	Open
Pipe PIPE12	100.00	1.13	0.88	0.022	0.00	0.00	Open
Pipe PIPE2	350.00	2.23	2.26	0.019	0.00	0.00	Open
Pipe PIPE14	50.00	0.57	1.22	0.122	0.00	0.00	Open
Pump 1	350.00	0.00	-116.78	0.000	0.00	0.00	Open
Valve 2	350.00	3.97	31.44	0.000	0.00	0.00	Active

 Network Table - Nodes

Node ID	Demand GPM	Head ft	Pressure psi	Quality
Junc JUN1	0.00	143.91	47.19	0.00
Junc JUN2	0.00	120.33	37.00	0.00
Junc JUN3	0.00	118.13	35.64	0.00
Junc JUN4	0.00	116.70	34.96	0.00
Junc SERV2	50.00	113.43	33.53	0.00
Junc JUN6	0.00	111.87	33.33	0.00
Junc SERV3	50.00	110.91	33.16	0.00
Junc JUN8	0.00	107.66	32.66	0.00
Junc JUN9	0.00	105.17	31.25	0.00
Junc SERV4	50.00	104.65	31.02	0.00
Junc SERV5	50.00	104.46	30.94	0.00
Junc SERV6	50.00	103.19	30.39	0.00
Junc SERV7	550.00	103.05	30.33	0.00
Junc SERV1	50.00	119.60	36.64	0.00
Resvr RES1	-850.00	35.00	0.00	0.00

 Network Table - Links

Link ID	Flow GPM	Velocity fps	Unit Headloss ft/Kft	Friction Factor	Reaction Rate mg/L/d	Quality	Status
Pipe PIPE3	800.00	5.11	10.26	0.017	0.00	0.00	Open
Pipe PIPE4	800.00	9.08	54.86	0.021	0.00	0.00	Open
Pipe PIPE5	800.00	9.08	43.61	0.017	0.00	0.00	Open
Pipe PIPE6	750.00	8.51	39.02	0.017	0.00	0.00	Open
Pipe PIPE7	750.00	8.51	43.62	0.019	0.00	0.00	Open
Pipe PIPE8	700.00	7.94	32.86	0.017	0.00	0.00	Open
Pipe PIPE9	700.00	7.94	34.09	0.017	0.00	0.00	Open
Pipe PIPE10	700.00	7.94	47.20	0.024	0.00	0.00	Open
Pipe PIPE11	650.00	7.38	194.55	0.115	0.00	0.00	Open
Pipe PIPE12	600.00	6.81	24.92	0.017	0.00	0.00	Open
Pipe PIPE2	850.00	5.43	11.85	0.017	0.00	0.00	Open
Pipe PIPE14	550.00	6.24	139.75	0.116	0.00	0.00	Open
Pump 1	850.00	0.00	-108.91	0.000	0.00	0.00	Open
Valve 2	850.00	9.65	23.58	0.000	0.00	0.00	Active



2260 Douglas Blvd., Suite 160 Roseville, CA 95661
P 916-772-7800 F 916-772-7804
www.cwecorp.com

September 13, 2023

Allen Sigl
CSG Consultants
1303 J St, Suite 270
Sacramento, CA 95814

Re. COM-2307306/CSF 23F-2105 905 North Ave

Dear Allen,

Please find the following civil improvement plans for your review and approval. Below are the response to comments:

1. Provide access turning radii to be 35 feet inside and 55 feet outside

Response: Fire turning radii shown on sheet C5.

2. Provide KNOX for vehicle access gates.

Response: There are no vehicle access gates proposed for this project.

3. Provide civil stamps on plans to be signed.

Response: Civil improvement plans are stamped and signed.

4. Provide all existing and new fire hydrants on civil water plan

Response: Existing fire hydrants annotated on sheet C7. City of Sacramento DOU stated that no onsite fire hydrants will be needed.

5. Provide and show any water line for fire sprinkler systems.

Response: There are fire sprinkler systems for the residential units. Water from the domestic water service will be used for the individual units.

Please review these plans and advise of your approval. If you should have any questions or need further clarification on the plans, please don't hesitate to call this office.

Sincerely,

CWE

Aaron Bernatchy

Aaron Bernatchy, E.I.T.
Engineer I